



LUND UNIVERSITY

Anti-windup in mid-ranging control

Haugwitz, Staffan; Henningsson, Maria; Velut, Stéphane; Hagander, Per

Published in:

Proceedings of the 44th IEEE Conference on Decision and Control and the 2005 European Control Conference

DOI:

[10.1109/CDC.2005.1583383](https://doi.org/10.1109/CDC.2005.1583383)

2005

[Link to publication](#)

Citation for published version (APA):

Haugwitz, S., Henningsson, M., Velut, S., & Hagander, P. (2005). Anti-windup in mid-ranging control. In *Proceedings of the 44th IEEE Conference on Decision and Control and the 2005 European Control Conference* (pp. 7570-7575). IEEE - Institute of Electrical and Electronics Engineers Inc..
<https://doi.org/10.1109/CDC.2005.1583383>

Total number of authors:

4

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

Anti-windup in mid-ranging control

Staffan Haugwitz, Maria Karlsson, Stéphane Velut and Per Hagander

Abstract—The implementation of anti-windup methods in mid-ranging control needs further attention. It is demonstrated how use of standard anti-windup schemes may give unnecessary performance degradation during saturation. The problem is illustrated for two separate systems, control of oxygen concentration in a bio-reactor and temperature control of a cooling system. In the paper, guidelines are derived for how to design the standard anti-windup scheme to recover performance. As an alternative a modified anti-windup scheme for mid-ranging control is presented that minimizes the performance degradation during saturation.

I. INTRODUCTION

In the process industry most control loops are single-input single-output (SISO). The use of additional inputs of the process for control purposes is often considered to increase control authority, performance or flexibility. When a process has more control inputs than outputs, the question arises how to use the additional degrees of freedom. The general control problem for this type of processes is sometimes referred to as control allocation, see [1], i.e. how the control actions should be distributed among the available control signals to control the process output.

A specific example of control allocation is mid-ranging. As stated in [2] mid-ranging refers to control problems where there are two control inputs and only one output to control. Often the inputs differ significantly in their dynamic effect on the output, and the faster input is in some way more costly to use than the slow one. In general the faster input, in this paper denoted u_1 , is also closer to saturation than the slower input, here denoted u_2 . The mid-ranging idea is to have the fast input u_1 controlling the process output, and to use the effect of the slower input u_2 to gradually reset or mid-range u_1 to its desired value $u_{1,ref}$. Thus u_2 indirectly acts to prevent saturation in u_1 and also to control the process mainly using the “cheaper” u_2 in stationarity. With the use of u_2 the operating range of the process is often considerably increased.

The general mid-ranging control structure is seen in Fig. 1. The mid-ranging idea has been around for many years under many different names, for example valve position control [3] or input resetting. It is commonly used in the process industry, but is also a key idea in e.g. the position control of the pickup-head in a CD-player.

The design method for C_1 and C_2 in Fig. 1 depends on the process. Normally PID-controllers are used, but all SISO controllers are possible, including Internal Model Control




Fig. 1. Mid-ranging control structure, for a process where G_3 represent common dynamics for u_1 and u_2 . In the bio-reactor example $G_1 = 1$, which will be used in the sequel.

(IMC) or Linear Quadratic Gaussian (LQG) control. For processes with more complex dynamics and/or time delays, the desired mid-ranging effect can be achieved using multi-variable control design, such as LQG or Model Predictive Control (MPC).

Papers such as [2], [4], [5] present tuning guidelines and applications of mid-ranging control, but there has so far been no discussion on anti-windup for this type of control structure. The main topic of this paper is how to implement anti-windup in mid-ranging control, and it will be demonstrated that standard anti-windup schemes may lead to unnecessary performance degradation during saturation.

II. PROBLEM STATEMENT

Processes with two input signals and one output signal can be represented with the block diagram in Fig. 1. In many situations like paper drying with steam and infrared light [4] it is reasonable to use the approximation $G_3 = 1$, while it is more natural to use $G_1 = 1$ for other processes like the bio-reactor described in Section III.

In standard applications of mid-ranging control, the dynamics in G_1 is significantly faster than that of G_2 . As a rule of thumb, the controllers C_1 and C_2 should therefore be tuned to keep the dynamics from y to u_1 an order of magnitude faster than the dynamics from y to u_2 to avoid exciting cross-couplings, violating control constraints in u_2 or obtaining a high closed-loop bandwidth at frequencies where there are generally large process uncertainties.

In this paper, standard mid-ranging control for a general process with saturation of u_1 is studied. When u_1 saturates, the unsaturated signal is used as input to C_2 . The controllers C_1 and C_2 can be tuned according to guidelines in for example [2]. When implemented, most PI-controllers have a standard anti-windup scheme [6], see Fig. 2. For more

All authors are with the department of Automatic Control, Lund Institute of Technology, Lund University, Box 118 SE-22100 Lund, Sweden. Corresponding author: Staffan Haugwitz, staffan.haugwitz@control.lth.se




Fig. 2. Basic scheme for anti-windup in a PID-controller.

general anti-windup methods, see for example [7]. The time constant T_i determines the speed with which the integral term is reset. In general T_i is chosen as $T_i \leq T_i$, where T_i is the integral time of the controller. In this paper, it will be demonstrated how applying this standard choice of T_i for C_1 can lead to unnecessary performance degradation when u_1 saturates because of decreased control authority of u_2 . Guidelines will be derived for design of anti-windup schemes for mid-ranging control structures to recover performance.

The paper is organized as follows. In Section III a bio-reactor application of mid-ranging control is presented. The disadvantages of using a standard choice of T_i will be demonstrated by simulation. In Section IV-A guidelines will be derived for how to choose a suitable time constant T_i to maintain the same control action in u_2 as in the unsaturated case. A modification that increases control action in u_2 to further reduce performance degradation will be presented in Section IV-B. The guidelines are also applied to a general purpose cooling/heating system in Section V. The aim is to show how the derived guidelines and modified control laws can be used for a process quite different from the bio-reactor. Finally, stability and performance for the proposed tuning are verified using theory for piecewise linear systems in Section VI.

III. MID-RANGING CONTROL OF A BIO-REACTOR

An example of a process where mid-ranging control can be applied is control of oxygen concentration in a stirred-tank bio-reactor used for cultivations of bacteria. Control of the bio-reactor is described in [8] and [9]. To ensure sufficient oxygen transfer to the cultivation medium, a mechanical stirrer is used with feed-back from the dissolved oxygen concentration to the stirrer speed. Bacterial growth leads to an exponentially increasing demand for oxygen, which causes the stirrer speed to saturate. The resulting decrease in dissolved oxygen concentration causes unnecessary stress on the bacteria, and also disables schemes for substrate feeding and monitoring of the cultivation that depend upon a constant dissolved oxygen concentration. The undesired effects may be avoided by mid-ranging the stirrer speed to a desired value by decreasing the reactor temperature. A lower temperature leads to decreased activity and reproduction of bacteria, thus reducing the oxygen demand. However, caution must be taken in the temperature control since the model is only valid within a limited temperature range, and a too low temperature

may significantly inhibit growth.

A linearized second-order model of the oxygen and temperature dynamics can be described by

$$\dot{x}(t) = Ax(t) + B_1 u_1(t) + B_2 u_2(t) \quad (1)$$

$$y(t) = Cx(t) \quad (2)$$

where the first state x_1 denotes the dissolved oxygen concentration which is also the process output y , and the second state x_2 denotes the reactor temperature. The two control signals u_1 and u_2 represent the stirrer speed and the reference temperature, respectively. The effect of the stirrer speed on y is much faster than that of the reference temperature. Numerical values for the system matrices used in simulations are given by

$$A = \begin{bmatrix} -2400 & -5200 \\ 0 & -15 \end{bmatrix} \quad (3)$$

$$\begin{bmatrix} B_1 & B_2 \end{bmatrix} = \begin{bmatrix} 210 & 0 \\ 0 & 15 \end{bmatrix}, \quad C = \begin{bmatrix} 1 & 0 \end{bmatrix} \quad (4)$$

For efficient use of the bio-reactor, it is essential to choose the reference value $u_{1,ref}$ for the stirrer speed close to the maximum value u_1^{max} . This narrow margin limits the control authority of u_1 around its reference value, and requires a sufficiently fast temperature controller to achieve acceptable responses to load disturbances.

PI-controllers are used for both C_1 and C_2 . The nominal control parameters in the following discussions are $K_1 = 10$, $T_{i1} = 1/120$ hours, $K_2 = 0.02$, $T_{i2} = 10/120$ hours, $u_1^{max} = 1200$ rpm and $u_{1,ref} = 0.98u_1^{max}$.

IV. ANTI-WINDUP

A. Standard anti-windup

During control design of C_1 and C_2 , the controllers are tuned mainly for the nominal, i.e. the unsaturated, case. The purpose of C_2 is to influence the process so that u_1 is mid-ranged to its reference value $u_{1,ref}$. C_2 also indirectly acts as an anti-windup scheme for u_1 , but the question arises whether C_1 needs additional support in terms of conventional anti-windup to reduce problems due to saturation.

When u_1 saturates at its maximum value u_1^{max} , the feedback loop of u_1 is broken, and instead all feedback has to go through u_2 . With fast anti-windup $u_1 \approx u_1^{max}$, which gives $u_2 \approx C_2(u_{1,ref} - u_1^{max})$. When the operating point is chosen such that $u_{1,ref}$ is close to u_1^{max} , the control error that C_2 acts on is very small, thus the contribution from u_2 to quickly end the saturation of u_1 is limited. It is then apparent that C_2 in the saturated case has decreased control authority, compared to the case when u_1 is not saturated. The performance is then significantly reduced as seen in Fig. 3 for the bio-reactor example. With fast anti-windup, u_2 adjusts very slowly resulting in a long period of saturation of u_1 . A standard choice of $T_i \leq T_i$ has consequently negative effects in the mid-ranging control setting.

Without anti-windup on the other hand, the characteristic wind-up phenomenon can be seen, with a large transient peak in the process output. Unless the controllers C_1 and C_2 are

well separated, disturbances may actually cause instabilities if no anti-windup is used.

The problem with fast anti-windup arises from loss of control authority of u_2 . It is possible to fix this problem by increasing the controller bandwidth, but this may not be feasible for all processes due to constraints on actuator dynamics or process uncertainties. Instead it is desirable to find a time constant T_i of the anti-windup scheme such that the control action in u_2 is the same in the saturated case as in the unsaturated case. That will be achieved by examining the bandwidth from r to u_2 in the two cases.

Given the block diagram in Fig. 1 with $G_1 = 1$, the transfer function from r to u_2 in the nominal case can be derived as

$$u_2 = -\frac{C_1 C_2}{1 + C_1 G_3 - C_1 G_3 G_2 C_2} r \stackrel{\text{def}}{=} G_{nom} r \quad (5)$$

The saturated case is less straight forward. The controllers and the process are governed by

$$y = G_3 \text{sat}(u_1) + G_3 G_2 u_2 \quad (6)$$

$$u_1 = C_1(r - y) + \frac{1}{(sT_i)}(\text{sat}(u_1) - u_1) \quad (7)$$

$$u_2 = C_2(u_{1,ref} - u_1) \quad (8)$$

In saturation¹ $\text{sat}(u_1) = u_1^{max}$. The reference control output $u_{1,ref}$ is assumed to be constant.

$$y = G_3 u_1^{max} + G_3 G_2 u_2 \quad (9)$$

$$u_1 = C_1(r - y) + \frac{1}{(sT_i)}(-u_1) + \frac{1}{(sT_i)}(u_1^{max}) \quad (10)$$

$$u_1 = \frac{sT_i}{(sT_i + 1)} C_1(r - y) + \frac{1}{(sT_i + 1)} u_1^{max} \quad (11)$$

$$u_2 = C_2(u_{1,ref} - u_1) \quad (12)$$

where we define $C_{aw} = sT_i/(sT_i + 1)$ from the anti-windup scheme. The broken feedback loop reduces the transfer function from r to u_2 as follows:

$$u_2 = -C_2 u_1 = -C_2(C_{aw} C_1(r - G_3 G_2 u_2)) \quad (13)$$

$$u_2 = -\frac{C_2 C_{aw} C_1}{(1 - C_2 C_{aw} C_1 G_3 G_2)} r \stackrel{\text{def}}{=} G_{sat} r \quad (14)$$

Note that the transfer function G_{sat} is parameterized in the anti-windup time constant T_i .

In order to have the same effect of u_2 in saturation as in the nominal case, i.e. the same bandwidth from r to u_2 , the transfer functions G_{nom} and G_{sat} should differ as little as possible. By examining the Bode diagrams of these transfer functions in Fig. 4, a value of $T_i = 1.2T_{i1}$ is chosen that improves performance during saturation for the bio-reactor compared to the extreme cases of fast and no anti-windup, respectively, see Fig. 3.

The suggested method for choosing T_i uses information on the nominal process and controllers, with the aim of minimizing the difference in the second control output between the constrained and the nominal case. It is independent of choice of reference value $u_{1,ref}$ in relation to u_1^{min} and u_1^{max} ,

¹Without loss of generality we consider only the upper limit on u_1 .




Fig. 3. Step response for bio-reactor example. Fast anti-windup (dashed), no anti-windup (dotted), nominal unsaturated system (solid), and T_i chosen to minimize the difference in Bode diagrams in Fig. 4 (dashed-dotted)




Fig. 4. Bode diagrams of the transfer function from r to u_2 for the bio-reactor example. Unsaturated case (solid), no anti-windup (dotted), fast anti-windup $T_i = T_{i1}/3$ (dashed) and $T_i = 1.2T_{i1}$ that minimizes the distance to the nominal case (dashed-dotted).

and is not limited to a particular disturbance model, or to particular reference trajectories.

B. Modified anti-windup scheme

So far the main criterion for choosing the anti-windup time constant T_i has been to obtain the same bandwidth from r to u_2 in the saturated case as in the nominal case. The control action in u_2 is then similar in the two cases.

Assume now that there is good process knowledge in G_3 and G_2 and constraints on u_1 and u_2 are well known. In this section an easy modification of the anti-windup scheme will be presented that improves the performance during saturation. By manipulating the input signal to C_2 during saturation, the use of u_2 can be increased without having to change the control parameters in C_2 . The modified anti-windup scheme can be seen in Fig. 5.




Fig. 5. Mid-ranging control structure with modified anti-windup scheme. The gain K_s increases the input signal to C_2 , thus generating higher control action in u_2 to improve performance when u_1 saturates.

$$\tilde{u}_1 = u_1 + K_s(u_1 - \text{sat}(u_1)) \quad (15)$$

$$u_2 = C_2(u_{1,ref} - \tilde{u}_1) = C_2(u_{1,ref} - u_1 - K_s(u_1 - \text{sat}(u_1))) \quad (16)$$

In the unsaturated case, the last term is zero as in the standard anti-windup scheme. When u_1 saturates, $\text{sat}(u_1) = u_1^{max}$ and $u_1 - u_1^{max} > 0$. The signal to C_2 is increased by the positive term $K_s(u_1 - u_1^{max})$. The modification allows for a standard anti-windup scheme with a small $T_t \leq T_i$ for fast integral reset, eliminating the windup phenomenon. The difference $u_1 - u_1^{max}$ is small using fast anti-windup, but with a suitable choice of K_s performance can be improved. Note that the additional input to C_2 , $u_1 - \text{sat}(u_1)$, is the same signal that is used for standard anti-windup of C_1 .

It is important to note that with this modification, the bandwidth of the transfer function from r to u_2 is increased. Caution should be used to avoid increasing the bandwidth into high frequency regions where there might be process uncertainties and also explicit constraints in u_2 . With the modification, the response from r to u_2 will be

$$u_2 = -\frac{C_2(K_s + 1)C_{aw}C_1}{(1 - C_2(K_s + 1)C_{aw}C_1G_2)}r \stackrel{def}{=} G_{K_s}r \quad (17)$$

As can be seen in Fig. 6, the low frequency part of G_{K_s} is not affected by K_s .

To find a suitable value of K_s a standard integral squared error cost function is used as performance criterion,

$$J = \int_0^{t_f} ((r - y)^2 + \rho u_2^2) dt \quad (18)$$

where ρ is a weight to compensate for scaling, or to suppress large use of u_2 . The objective is to find K_s that minimizes the cost function J , for example by numerical search or simulations. Step responses in dissolved oxygen for the bio-reactor with the modified anti-windup scheme are seen in Fig. 7. The performance with $K_s = 3$ is almost as good as the unsaturated case, due to the extra use of u_2 . In this case $\rho = 0.34$, if less control action in u_2 is desired, ρ should be increased. The optimal value of K_s depends on the reference r , C_2 and the choice of ρ . A larger reference step r will give larger control error $(r - y)$, thus favoring a higher K_s . For a faster C_2 , a lower K_s is needed for the same performance. The value of K_s will also vary depending on the choice of T_t , which should be small ($T_t \leq T_i$) to allow fast anti-windup.




Fig. 6. Bode diagram for transfer function from r to u_2 for bio-reactor with modified anti-windup scheme and different values of K_s . $T_t = T_{i1}$ has been used in all cases.




Fig. 7. Step response with modified anti-windup scheme for bio-reactor. Nominal case (solid), standard anti-windup with $T_t = 1.2T_{i1}$ (dotted), modified anti-windup with $T_t = T_{i1}$ and $K_s = 3$ (dashed). Lower right: cost function (18) evaluated for different values of K_s using $\rho = 0.34$.

Dead-beat anti-windup should however be avoided since it gives $u_1 = u_1^{max}$, which renders the modification ineffective.

As an alternative to mid-ranging control, Model Predictive Control could be used for the same types of processes. In MPC a similar cost function (18) is evaluated for a specified prediction horizon, and control action is then redistributed to u_2 as u_1 saturates. Performance of the closed-loop system can be further improved using MPC, but at the cost of the computational effort involved in on-line optimization.

The main advantages with the proposed simple modification of standard PID-control are that it is only active as long as u_1 saturates, and that the calculation is very simple and it can be implemented in most commercial PID packages. There is no need to change to a different set of control parameters in C_2 during saturation. A downside is the potential risk of over-using u_2 with the risk of exciting

unmodelled dynamics or violating constraints in u_2 . It is therefore essential to use a value of ρ that reflects the given process and its constraints. The modified closed-loop system should also be evaluated in simulations to verify performance.

V. COOLING SYSTEM

In this section the previously derived guidelines are applied on a different process to show that the results derived are in fact general. The process is a multi-purpose cooling system, which should transfer heat released from an exothermic reaction inside a heat exchange reactor [10].

The control variables u_1 and u_2 are the desired positions of two control valves and the output y is the inlet temperature of the cooling water for the reactor. The process can be approximated with two transfer functions with a common denominator, due to the cross-couplings introduced by the recycle loops. The dynamics correspond to the water temperatures of the cold and warm side of the heat exchanger and the cold side of the reactor, respectively.

$$y = \frac{-7.8(s+0.14)(s+0.036)u_1 - 1.1(s+1.9)(s+0.14)u_2}{(s+0.016)(s+0.017)(s+1.1)} \quad (19)$$

The process is well suited for mid-ranging control, due to the different dynamics from u_1 to y and u_2 to y .

The reference temperature for the cooling water is calculated by an MPC controller for the chemical reactor, see [10]. The objective of the cooling system controller is to track the given reference temperature as well as possible. The cooling temperature is solely determined by u_1 . Large reference changes or disturbances may cause saturation of u_1 . To improve performance and increase the operating region of the hydraulic equipment, u_2 is manipulated to mid-range u_1 to the desired value $u_{1,ref}$. To have suitable control margin $u_{1,ref} = 0$, which corresponds to an actual valve position of 50%. The constraints in u_1 are thus ± 0.5 .

PI-controllers are used for both C_1 and C_2 . The nominal control parameters in the following discussions are $K_1 = -0.03$, $T_{i1} = 1.0$ seconds, $K_2 = -0.05$, $T_{i2} = 30$ seconds.

A. Anti-windup for the cooling system

Also for the cooling system, a fast time constant T_i of the anti-windup scheme is not always advantageous. In Fig. 8 the closed-loop system is simulated when there is a step in the temperature reference with $r = 10^\circ\text{C}$ above the linearized operating point. The response is slow for fast anti-windup, whereas slow anti-windup gives faster response, but a larger overshoot due to windup.

Boode diagrams for the transfer functions (5) and (14) for different values of T_i are evaluated. By visual inspection $T_i = 4T_{i1}$ gives the saturated system a similar frequency response as the unsaturated system, see Fig. 9. As predicted, fast anti-windup gives lower gain, whereas slow anti-windup gives higher gain than the unsaturated case.

The step response for $T_i = 4T_{i1}$ is seen in Fig. 8. Note that the control action in u_2 is almost identical for the unsaturated




Fig. 8. Step responses for the cooling system. Nominal case without any constraints (solid), with fast anti-windup $T_i = 0.5$ (thick dashed), with no anti-windup (dotted), the case with $T_i = 4T_{i1}$ and $K_s = 0$ (dash-dot) and finally the case with the modified structure with fast anti-windup $T_i = 0.5$ and $K_s = 60$ (thin dashed). Lower right: cost function (18) evaluated for different values of K_s using $\rho = 150$ when $T_i = 0.5T_{i1}$.




Fig. 9. Bode plots of the transfer function from r to u_2 for cooling system. Unsaturated case (solid), the saturated cases when $T_i = 4T_{i1}$ (dashed), $T_i = 0.5T_{i1}$ (dash-dot) and $T_i = 50T_{i1}$ (dotted).

case and the case when $T_i = 4T_{i1}$, which was the purpose of our choice of T_i .

B. Modified anti-windup scheme for the cooling system

To improve performance of the cooling system when u_1 saturates, the modified anti-windup scheme presented in Section IV-B can be used. It is important to increase the control action in u_2 with caution, since higher controller bandwidth might excite unmodelled dynamics or also cause u_2 to saturate.

The cost function (18) is used. Based on available control authority in u_2 , a reasonable choice of ρ is 150. If less control action in u_2 is desired, ρ should be increased. From




Fig. 10. An upper bound on the L_2 -gain from d to y for varying T_i for the cooling system.

simulations, the cost function is evaluated for varying K_s , see Fig. 8. Standard fast anti-windup is used, $T_i = 0.5T_{i1}$. There is a clear minimum for $K_s = 60$. With the modified anti-windup scheme the performance is significantly improved, due to the increased use of u_2 during the short time u_1 is saturated.

VI. GLOBAL STABILITY AND PERFORMANCE ANALYSIS

Input-output stability for the bio-reactor using the proposed method for choice of T_i has been ensured using the circle criterion in [9]. We can also use the fact that the closed-loop system is piecewise linear for both the conventional anti-windup scheme discussed in Section IV-A and the modified scheme in section IV-B. Various tools are available for stability and performance analysis of such systems, see for example [11] and [12].

The proposed choice of T_i is based on local analysis and showed improvement compared to the case with a standard choice of $T_i \leq T_i$. To provide a global analysis, the cooling system from Section V is studied using algorithms from [11]. Stability can be derived using a piecewise quadratic Lyapunov function.

The performance is verified by calculating an upper bound of the L_2 -gain from a disturbance d on the control signal u_1 to y for various values of T_i , see Fig. 10. We see that the extreme cases with fast or slow anti-windup have a significantly larger L_2 -gain from d to y . Note also that the standard choice $T_i \leq T_i$ also gives unnecessarily low performance. The results from the local analysis indicating that $T_i = 4T_{i1}$ gives better results are confirmed by the global analysis.

VII. SUMMARY

We have presented two rather different applications of mid-ranging control, a bio-reactor and a cooling system. We have examined the effects of anti-windup for the fast controller C_1 when the corresponding control output u_1 is subject to saturation. It has been shown that default choices of anti-windup constant T_i are not applicable to the mid-ranging control structure since they decrease the control authority of the slow control variable u_2 . However, removing the

anti-windup mechanism leads to the characteristic windup phenomenon and potentially even to instability.

We have suggested a method to choose the anti-windup parameter T_i that aims to minimize the difference in control action of u_2 between the nominal and the saturated case. This is achieved by examining the Bode diagrams of the transfer function from r to u_2 for the nominal case as well as the saturated case for different values of T_i . The advantage of this method is that it deviates as little as possible from the original control design to avoid excitation of unmodelled process dynamics and cross-couplings between the control variables. The method improves the performance for both of the studied processes when u_1 saturates, compared to using either no anti-windup or a default choice of T_i .

However, the saturation naturally leads to inferior performance compared to the unsaturated case. If the process configuration allows for increased bandwidth of the slow controller C_2 when u_1 saturates, we suggest a modified anti-windup structure that does not change the nominal controller design, but gives an increased control input to C_2 when u_1 saturates. This structure is parameterized in a constant K_s . Using numerical optimization of an integral square cost function (18) to determine K_s , it is here possible to obtain a performance comparable to the nominal case without altering the nominal design.

The stability and performance of the global system with saturation can be analysed using theory of piecewise linear systems. The result from the global analysis supports the local analysis on how to choose a suitable anti-windup scheme.

REFERENCES

- [1] W. Durham, "Constrained control allocation," *Journal of Guidance, Control and Dynamics*, vol. 16, no. 4, pp. 717–725, 1993.
- [2] B. J. Allison and S. Ogawa, "Design and tuning of valve position controllers with industrial applications," *Transactions of the Institute of Measurement and Control*, vol. 25, pp. 3–16, 2003.
- [3] F. Shinskey, *Process Control Systems*. McGraw-Hill, 1996.
- [4] B. J. Allison and A. J. Isaksson, "Design and performance of mid-ranging controllers," *Journal of Process Control*, vol. 8, pp. 469–474, 1998.
- [5] M. Karlsson, O. Slätteke, B. Wittenmark, and S. Stenström, "Reducing moisture transients in the paper-machine drying section with the mid-ranging control technique," *Nordic Pulp and Paper Research Journal*, vol. 20, no. 2, pp. 150–156, June 2005.
- [6] K. J. Åström and T. Hägglund, *PID Controllers: Theory, Design, and Tuning*. Research Triangle Park, North Carolina: Instrument Society of America, 1995.
- [7] N. Kapoor, A. Teel, and P. Daoutidis, "An anti-windup design for linear systems with input saturation," *AUTOMATICA*, vol. 34, no. 5, pp. 559–574, 1998.
- [8] S. Velut, L. de Maré, and P. Hagander, "A modified probing feeding strategy: control aspects," *Reglermöte 2004*, May 2004.
- [9] M. Karlsson, "Control of bacillus subtilis cultivations - feeding strategies and the role of anti-windup in mid-ranging control," Department of Automatic Control, Lund Institute of Technology, Sweden, Master's thesis ISRN LUTFD2/TFRT-5745--SE, May 2005.
- [10] S. Haugwitz and P. Hagander, "Process control of an Open Plate Reactor," in *Proceedings of IFAC World Congress*, July 2005.
- [11] S. Hedlund and M. Johansson, "PWLTool, a Matlab toolbox for piecewise linear system," Department of Automatic Control, Lund Institute of Technology, Sweden, Tech. Rep. ISRN LUTFD2/TFRT-7582--SE, Mar. 1999.
- [12] A. Rantzer and M. Johansson, "Piecewise linear quadratic optimal control," *IEEE Trans. on Automatic Control*, 2000.