



LUND UNIVERSITY

Automatic Tuning of PID Controllers Based on Dominant Pole Design

Hägglund, Tore; Åström, Karl Johan

1985

Document Version:

Publisher's PDF, also known as Version of record

[Link to publication](#)

Citation for published version (APA):

Hägglund, T., & Åström, K. J. (1985). *Automatic Tuning of PID Controllers Based on Dominant Pole Design*. (Technical Reports TFRT-7299). Department of Automatic Control, Lund Institute of Technology (LTH).

Total number of authors:

2

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

CODEN: LUTFD2/(TFRT-7299)/1-6/(1985)

Automatic Tuning of PID Controllers Based on Dominant Pole Design

T Hägglund
K J Åström

Department of Automatic Control
Lund Institute of Technology
October 1985

Department of Automatic Control Lund Institute of Technology P.O. Box 118 S-221 00 Lund Sweden		<i>Document name</i> INTERNAL REPORT	
		<i>Date of issue</i> October 1985	
		<i>Document Number</i> CODEN: LUTFD2/(TFRT-7299)/1-6/(1985)	
<i>Author(s)</i> T Hägglund and K J Åström		<i>Supervisor</i>	
		<i>Sponsoring organisation</i>	
<i>Title and subtitle</i> Automatic tuning of PID controllers based on dominant pole design			
<i>Abstract</i> This paper describes a new method for designing simple feedback systems. The idea is to position only those loop poles which have a dominant influence on the closed loop response. Techniques for approximate determination of the dominant poles are derived, as well as design methods based on these formulas. The design methods are shown to be suitable for automatic tuning of PID controllers.			
<i>Key words</i>			
<i>Classification system and/or index terms (if any)</i>			
<i>Supplementary bibliographical information</i>			
<i>ISSN and key title</i>			<i>ISBN</i>
<i>Language</i> English	<i>Number of pages</i> 6	<i>Recipient's notes</i>	
<i>Security classification</i>			

The report may be ordered from the Department of automatic control or borrowed through the University Library 2, Box 1010, S-221 03 Lund, Sweden, Telex: 33248 lubbis lund.

AUTOMATIC TUNING OF PID CONTROLLERS BASED ON DOMINANT POLE DESIGN

T Hägglund and K J Åström

Department of Automatic Control, Lund Institute of Technology
Lund, Sweden

Abstract:

This paper describes a new method for designing simple feedback systems. The idea is to position only those closed loop poles which have a dominant influence on the closed loop response. Techniques for approximate determination of the dominant poles are derived, as well as design methods based on these formulas. The design methods are shown to be suitable for automatic tuning of PID controllers.

1. INTRODUCTION

This paper was motivated by work on automatic tuning of simple regulators. See Åström and Hägglund (1983, 1984a, 1984b) which indicated the need for improved design methods for simple regulators of the PID type. The classical Ziegler-Nichols tuning rules have the advantage of being very simple to use since they are based on knowledge of one point on the Nyquist curve of the system only. See Ziegler and Nichols (1943). The Ziegler-Nichols design method does, however, give poor control of the damping of the closed loop system. Related methods based on amplitude and phase margins discussed in Åström and Hägglund (1984a) also have the same difficulty. See Hägglund and Åström (1984).

A natural extension of the Ziegler-Nichols method is to try to find techniques which are based on knowledge of several points on the Nyquist curve of the open loop system. In Hägglund and Åström (1984), a new method was proposed which uses two points on the Nyquist curve. It may be regarded as a special case of pole-placement where it is only attempted to position the dominant closed loop poles. This is in contrast to normal pole placement methods where all closed loop poles are positioned. The design was derived using conformal mapping arguments. In this paper, a more general derivation of the dominant pole design method is presented. It contains the method of Hägglund and Åström (1984) as a special case.

The paper is organized as follows. The notion of dominant poles is reviewed in Section 2. Approximate methods for determining the dominant poles are given in Section 3. The key result is a very simple method for determining poles from the Nyquist curve of the loop transfer function. The formula developed in Section 3 is used to derive design methods for PI, PD and PID-regulators in Section 4. The specifications given are primarily related to the frequency and the damping of the dominant poles. A few examples of the application of the design method are also given. In Section 5, an auto-tuning method suitable for the design method is reviewed. In Section 6, the design method is used to control several models of processes which are common in process control. The main results of the paper are summarized in Section 7, and references are given in Section 8.




Fig. 1 Block diagram of a simple feedback system.

2. DOMINANT POLES

Consider a closed loop system obtained by negative feedback around a linear system with the transfer function $G(s)$. See Fig. 1. The transfer function of the closed loop system from the command signal to the output is given by

$$G_c(s) = \frac{G(s)}{1+G(s)} \quad (2.1)$$

Many properties of the closed loop system can be deduced from the poles and the zeros of $G_c(s)$. The zeros of $G_c(s)$ are the same as the zeros of $G(s)$ i.e. the zeros of the plant and the regulator. The closed loop poles are the roots of the equation

$$1 + G(s) = 0 \quad (2.2)$$

The pole-zero configurations of closed loop systems may vary considerably. Many simple feedback loops will, however, have a configuration of the type shown in Fig. 2 where the principal characteristics of the response is given by a complex pair of poles p_1, p_2 called the dominant poles. The response is also somewhat influenced by real poles and zeros, p_3 and z_1 , respectively. The steady state properties are influenced by the dipole p_4, z_2 . Poles and zeros whose real parts are much smaller than the real part of the dominant poles have little influence on the transient response. Classical control was very much concerned with closed loop systems having the pole-zero configuration shown in Fig. 2. See Mulligan (1949), Truxal (1955), Elgerd and Stephens (1959), Horowitz (1963).




Fig. 2 Pole-zero configuration of a simple feedback system.

3. DETERMINATION OF DOMINANT POLES

A simple method for estimating the dominant poles from knowledge of the Nyquist curve of the open loop system will now be described. Consider the loop transfer function G as a map from the s -plane to the G -plane. See Fig. 3. The map of the imaginary axis in the s -plane is the Nyquist curve which is indicated by the full line in Fig. 3b. The closed loop poles are given by the characteristic equation

$$G(s) + 1 = 0$$

Therefore, the map of a straight line through the dominant poles in the s -plane is a curve which goes through the critical point $C = -1$ in the G -plane. This curve is dashed in Fig. 3b. Since the map is conformal, the straight line $A'C'$ is mapped into the curve AC which intersects the Nyquist curve orthogonally. The triangle $A'B'C'$ is also mapped conformally to ABC . If ABC can be approximated by a triangle the following condition holds

$$\frac{G(i\omega_2) - G(i\omega_1)}{i\omega_2 - i\omega_1} = \frac{1+G(i\omega_2)}{\sigma} \quad (3.1)$$

This equation can be used to determine the dominant poles approximatively. The procedure can be expressed as follows. Determine a point A on the Nyquist curve such that the normal at A goes through the critical point C . The frequency ω_2 at A is then the argument such that $G(i\omega_2) = A$. To determine σ consider a neighbouring point ω_1 and compute σ from (3.1). The approximation will be good if the graph ABC is close to a triangle.

An analytic derivation

To provide further insight, the equation (3.1) will now be derived analytically. For this purpose consider the equation (2.2). A Taylor series expansion around $s = i\omega$ gives

$$0 = 1 + G(-\sigma + i\omega) = 1 + G(i\omega) - \sigma G'(i\omega) + \dots$$

Neglecting terms of second and higher order in σ we find

$$1 + G(i\omega) - \sigma G'(i\omega) = 0 \quad (3.2)$$

This equation is equivalent to (3.1) as $\omega_1 \rightarrow \omega_2 = \omega$. Notice that ω must be chosen so that the normal to the Nyquist curve at ω goes through the critical point. Otherwise σ in (3.2) will not be real. This analytic derivation shows that the formula (3.1) will give good results for small σ , i.e. when the dominant poles are close to the imaginary axis. The approximation (3.2) will not hold if the function $G(s)$ has singularities inside the circle with center in $i\omega$ and radius ω . This means that σ must be smaller than ω .

An example which illustrates the formula (3.2) for approximative determination of the dominant poles will now be given.




Fig. 3 Representation of the transfer function G as a map of C to C .

EXAMPLE 3.1

Consider a system with the loop transfer function

$$G(s) = \frac{k}{s(s+1)^2}$$

Hence

$$G'(s) = -\frac{k}{s^2(s+1)^2} - \frac{2k}{s(s+1)^3}$$

Equation (3.2) becomes

$$s^5 + 3s^4 + 3s^3 + (1+k)s^2 + k(1+3\sigma)s + \sigma k = 0$$

Introducing $s = i\omega$ gives two real equations with the solution

$$\sigma = \frac{(8-k)\sqrt{32k+9k^2} - 24k - 3k^2}{128k}$$

$$\omega = \sqrt{\frac{3k + \sqrt{32k + 9k^2}}{16}}$$

For $k = 1$ the solution becomes

$$\sigma = 0.14 \quad (0.122)$$

$$\omega = 0.77 \quad (0.745)$$

$$\zeta = 0.18 \quad (0.16)$$

The correct values are given in parentheses. $\square$

Difference approximations

Equation (3.1), which may be considered as a difference approximation of (3.2), is more convenient to use than (3.2) when the Nyquist curve is determined experimentally. The equation (3.1) can be written as

$$\sigma = \frac{i(\omega_2 - \omega_1) [1 + G(i\omega_2)]}{G(i\omega_2) - G(i\omega_1)} \quad (3.3)$$

Notice that the complex numbers $1 + G(i\omega_2)$ and $G(i\omega_2) - G(i\omega_1)$ are orthogonal if ω_1 and ω_2 are properly chosen. The frequency ω can then also be estimated as $\omega = \omega_2$. Two points on the Nyquist curve are obviously needed to use this formula. More accurate equations can be derived if more points are known.

4. DOMINANT POLE DESIGN

A control design problem will now be presented. Consider the closed loop system shown in Fig. 4 with a plant and a compensator. The compensator G_R should be determined so that the closed loop system has desired properties. Assume that the closed loop system can be characterized by the dominant poles, $s = -\sigma \pm i\omega$. The transient behaviour is then largely governed by σ and ω . It is also influenced by the zeros of the process and the regulator to some extent.




Fig. 4 Block diagram of a closed loop system.

Since the dominant poles are characterized by two parameters, a regulator of the PI or PD type which has two adjustable parameters is sufficient to give desired dominant poles, provided that the desired bandwidth is not too high. A PID-regulator which has an additional parameter adds extra flexibility with respect to rejection of load disturbances.

A design procedure

With these specifications it is straightforward to obtain an analytic formula for the design. Equation (3.2) gives the following condition

$$\left[1 + G_p G_R \right] - \sigma \left[G_p' G_R + G_p G_R' \right] = 0 \quad (4.1)$$

This is an equation in complex variables. It thus gives two real equations which can be used to determine the parameters of a PI or a PD regulator. Since a PID-regulator has three parameters, an auxiliary condition is needed in this case. Such a condition can be to specify a given relation between the integral time T_i and the derivative time T_d , i.e.

$$T_d = \alpha T_i \quad (4.2)$$

A regulator also introduces zeros in the loop transfer function. These zeros are influenced by the manner in which the command signal is introduced in the system. It is common practice not to introduce the command signal in the derivative action. Such a PID-regulator can be described by

$$u = K \left[e_p + \frac{1}{T_i} \int_0^t e(s) ds + T_d \frac{de_d}{dt} \right] \quad (4.3)$$

where

$$e_p = e = r - y, \quad e_d = -y$$

The regulator introduces a zero at

$$s = -\frac{1}{T_i}$$

This zero may cause an excessive overshoot if it is too close to the real part of the dominant poles. To avoid this the regulator may be modified by choosing

$$\begin{cases} e = r - y \\ e_p = \beta r - y \\ e_d = -y \end{cases} \quad 0 < \beta \leq 1 \quad (4.4)$$

This means that the proportional part only acts on a fraction β of the reference signal. The regulator (4.3) with e_p , e_d and e defined by (4.4) introduces a zero at

$$s = -\frac{1}{\beta T_i}$$

This zero can be positioned properly by selecting β . A reasonable choice is

$$\beta = \frac{1}{3\sigma T_i} \quad (4.5)$$

since this choice will place the zero at -3σ , which is far away from the real part of the dominant poles.

Summarizing we find that the design procedure can be described as follows. Determine the parameters of the regulator such that (4.1), (4.2) and (4.3) hold. The design procedure is illustrated by several examples in Section 6.

Examples

This section ends with some examples where only PI or PD regulators are used. In these cases, the controller is uniquely determined by Equation (4.1).

EXAMPLE 4.1 - PD control of a double integrator

With PD-control of a double integrator the loop transfer function becomes

$$G(s) = \frac{k + k_d s}{s^2} = \frac{k}{s^2} + \frac{k_d}{s}$$

where k is the proportional gain and k_d is the derivative gain. Solving the design equation (4.1) for k and k_d gives

$$k = \frac{\omega^4}{2\sigma^2 + \omega^2} \approx \left[\omega^2 + \sigma^2 \right] \left[1 - \frac{3\sigma^2}{\omega^2} \right]$$

$$k_d = \frac{2\sigma\omega^2}{2\sigma^2 + \omega^2} \approx 2\sigma \left[1 - \frac{2\sigma^2}{\omega^2} \right]$$

where the approximations yield if σ/ω is small. With PD-control of a double integrator it is possible to obtain an arbitrary pole placement. The exact gains which give the poles $-\sigma \pm i\omega$ are $k = \omega^2 + \sigma^2$ and $k_d = 2\sigma$. □

The gains in Example 4.1 give a closed loop system with a frequency ω_1 and a relative damping ξ_1 equal to

$$\omega_1 = \sqrt{k - k_d^2/4} = \omega \frac{\sqrt{\omega^4 + \sigma^2 \omega^2}}{\omega^2 + 2\sigma^2} \approx \omega \left[1 - \frac{3}{2} \frac{\sigma^2}{\omega^2} \right]$$

$$\xi_1 = \frac{k_d}{2\sqrt{k}} = \frac{\sigma}{\sqrt{\omega^2 + \sigma^2}} \cdot \frac{\sqrt{\omega^2 + \sigma^2}}{\sqrt{\omega^2 + 2\sigma^2}} \approx \xi \left[1 - \frac{\sigma^2}{2\omega^2} \right]$$

The equations indicate the error due to the approximations used. Notice that the error in the relative damping is smaller than the error in the frequency. With $\sigma/\omega = 0.5$ the error in the relative damping is 9 % while the error in the frequency is about 25 %. The errors may be reduced by using more terms in the Taylor series expansion used to derive the design equation.

Next a plant with the transfer function

$$G_p(s) = \frac{1}{(s+1)^3} \quad (4.6)$$

will be investigated. Since the plant is of third order it is clear that exact pole placement cannot be obtained with PI, PD or PID-control. First consider PI-control.

EXAMPLE 4.2 - PI control of $(s+1)^{-3}$

With PI-control of the system (4.6), the loop transfer function is

$$G(s) = \frac{k}{(s+1)^3} + \frac{k_i}{s(s+1)^3}$$

Solving the design equation (4.1) for k and k_i gives

$$k = \frac{\sigma(-4\omega^4 + 20\omega^2) + 3\omega^4 + 2\omega^2 - 1}{\omega^2 + 12\sigma^2 + 6\sigma + 1}$$

$$k_i = \frac{-\omega^6 + 2\omega^4 + 3\omega^2 - 12\sigma(\omega^4 - \omega^2)}{\omega^2 + 12\sigma^2 + 6\sigma + 1}$$

□

EXAMPLE 4.3 - PD control of $(s+1)^{-3}$

Consider PD-control of the system (4.6). The loop transfer function becomes

$$G(s) = \frac{k+k_d s}{(s+1)^3}$$

The design equation (4.1) has the solution

$$k = \frac{-2\sigma\omega^4 + 3\omega^4 + 16\sigma\omega^2 + 2\omega^2 - 6\sigma - 1}{\omega^2 + 6\sigma^2 + 6\sigma + 1}$$

$$k_d = \frac{\omega^4 + 12\sigma\omega^2 - 2\omega^2 - 12\sigma - 3}{\omega^2 + 6\sigma^2 + 6\sigma + 1}$$

In the Examples 4.2 and 4.3, regulators with positive gains can be found only if the specifications on the dominant poles are restricted to certain areas. Fig. 5 shows those combinations of σ and ω which give positive gains for the PI and the PD regulators respectively. The border-lines are given by the pure P, I and D regulators. Notice that the approximative formulas are only valid if $\sigma < \omega$. From this figure it is seen that the bandwidth ω cannot be chosen too high if only a PI controller is used.

How to find a proper ω

The choice of a proper ω is crucial in the dominant pole design. Since a PID regulator has a limited complexity, it is clear that arbitrarily large values of ω can not be chosen. This is also clearly illustrated in the examples. See Fig. 5. It is also clear that the approach will always work for open loop stable systems if ω is chosen sufficiently low.

Guidelines for possible values of ω can be obtained as follows. The open loop cross over frequency ω_c can serve as a first approximation. The phase lead generated by a PID regulator depends on the ratio $\alpha = T_d/T_i$ and the maximum derivative gain. With $\alpha = 0.25$ the largest lead is approximately 40° . This means that a proper phase margin may be obtained with $\omega = \omega_c$. To obtain a good transient response it is, however, also necessary that the slope $d\log|G(j\omega)|/d\log\omega$ is close to -1 at the crossover. Evaluation of the slope at the open loop cross over frequency gives an indication if the cross over frequency can be chosen as ω . There is again some margin. A PID regulator can e.g. increase the slope by at most 0.4 when $\alpha = 0.25$. If the slope conditions can not be satisfied, a lower value of ω must be chosen.

By evaluating how rapidly the phase changes we can also get an indication if the dynamics is dominated by time delays. In these cases the rule (4.2) is not appropriate. It is much better with pure PI control.




Fig.5 Areas of positive gains in the PI and PD regulators.

5. AUTO-TUNING

If the dominant pole design method is combined with some method for automatic determination of two points on the Nyquist curve, an auto-tuning method can be derived. In Åström and Hägglund (1984b), a method to automatically identify points on the Nyquist curve is presented. The identification procedure automatically determines the frequencies as well as the values of the open loop transfer function at points in the neighborhood of the cross over frequency. It is therefore well suited for the dominant pole design. The method will be shortly reviewed.

The technique is based on the observation that a system with a phase lag of at least π at high frequencies may oscillate with period t_c under relay control. To determine the critical point the system is connected in a feedback loop with a relay as is shown in Fig. 6. The error e is then a periodic signal, and the parameters k_c and ω_c can be determined approximatively from the first harmonic component of the oscillation.

Let d be the relay amplitude and let a be the amplitude of the first harmonic of the error signal. A Fourier series expansion gives that the first harmonic of the relay output has the amplitude $4d/\pi$. The following condition is then obtained by tracing signals around the feedback loop.

$$G(j\frac{2\pi}{t_c}) = \frac{\pi a}{4d} \quad (5.1)$$

This result also follows from the describing function approximation because the describing function of a relay is given by $N(a) = 4d/\pi a$. Notice that the technique will automatically generate an input signal to the process which has a significant frequency content at ω_c . This ensures that the critical point can be determined accurately.

The period of the limit cycle oscillation can easily be determined from the times between zero-crossings. The amplitude may be determined by measuring the peak-to-peak values of the output. These estimation methods are easy to implement because they are based on counting and comparisons only. Since the describing function analysis is based on the first harmonic of the oscillation, the simple estimation techniques require that the first harmonic dominates. If this is not the case, it may be necessary to filter the signal before measuring. More elaborate estimation schemes like least squares estimation and extended Kalman filtering may also be used to determine the amplitude and the frequency of the limit cycle oscillation. Simulations and experiments on industrial processes have indicated that little is gained in practice by using more sophisticated methods for determining the amplitude and the period.

There are many variations of the scheme. Other points on the Nyquist curve can be estimated by introducing known dynamics and hysteresis in the relay. See Åström and Hägglund (1984a,b). The negative reciprocal of the describing function of such a relay is

$$-\frac{1}{N(a)} = -\frac{\pi}{4d} \sqrt{a^2 - \epsilon^2} - i \frac{\pi \epsilon}{4d} \quad (5.2)$$




Fig. 6 Block diagram of the auto-tuner. The system operates as a relay controller in the tuning mode (t) and as an ordinary PID regulator in the control mode (c).

where d is the relay amplitude and ϵ is the hysteresis width. This function can be regarded as a straight line parallel to the real axis, in the complex plane. See Fig. 7.

Two experiments with relay feedback having different ratios ϵ/d give the information about the process which is needed in order to apply the design method given in Section 3. This estimation method is in good harmony with the dominant pole design technique, because it will give the open loop cross over frequency. By introducing a small amount of hysteresis in the relay we can also obtain the open loop transfer function at a neighboring point. By evaluating the gradient of the open loop transfer function we can then determine if the cross over frequency is a good candidate for ω . If it is, the PID parameters are straightforwardly given by the dominant pole design. See equation (3.1). If the cross over frequency is not an achievable bandwidth ω , we can find another candidate for ω from a relay oscillation experiment with larger hysteresis.

6. SIMULATION EXAMPLES

In this section, the dominant pole design is applied to some systems which have dynamics that is common in process control. The identification procedure described in the previous section is used in the following examples. The desired relative damping of the dominant poles is chosen to $\zeta = 0.4$. The PID controller has the structure given by Equation (4.3), with the relation α between the integral time and the derivative time equal to 0.25. See Equation (4.2). The parameter β is chosen according to Equation (4.5).

Processes with the following transfer functions were used

$$G_1 = \frac{1}{s} \quad G_2 = \frac{1}{s+1} \quad n_{nn} \quad G_3 = \frac{1}{(s+1)^3}$$

$$G_4 = \frac{1}{(s+1)^6} \quad G_5 = \frac{1}{(1+s)(1+0.2s)(1+0.05s)(1+0.01s)}$$

$$G_6 = \frac{1}{(s+1)^2} e^{-0.4s} \quad G_7 = \frac{1}{(s+1)^2} e^{-2s} \quad G_8 = \frac{1}{(s+1)^2} e^{-4s}$$

The PID parameters and the frequency ω of the dominant poles are presented in the following table.

	ω	K	T_i	T_d	β
G_1	15.8	21.0	0.169	0.0422	0.29
G_2	15.7	24.7	0.185	0.0464	0.26
G_3	1.71	3.71	2.28	0.571	0.20
G_4	0.578	1.23	4.61	1.15	0.29
G_5	9.52	9.62	0.492	0.123	0.16
G_6	2.14	3.20	1.54	0.385	0.23
G_7	0.880	0.939	2.64	0.661	0.33
G_8	0.555	0.593	3.67	0.917	0.38

In Fig. 8 - 15, the result of the simulations are presented. The figures show the output signals y above the input signals u . The systems are disturbed by a set-point change followed by a constant load disturbance.

The dominant pole design manages to control all the processes satisfactory. The process G_8 has a time delay which is quite long compared to the time-constant of the system. These processes are known to be difficult to control with a PID regulator without dead-time compensation. Processes with several different time-constants, like the process G_5 , is known to be poorly controlled when the Ziegler-Nichols design is used.




Fig. 7 The negative reciprocal of the describing function $N(a)$, and the Nyquist curve of $G(s)$.

The cross over frequency was chosen as the desired ω in all cases, except for G_1 and G_2 . The slope of the amplitude curve at the cross over for the system G_3 is -2.1, which indicates that the cross over frequency is too high in this case. This is also indicated by the droop in the step response. The phase gradients are high for G_4 , G_7 and G_8 indicating dominating time delay.




Fig. 8 G_1




Fig. 9 G_2




Fig. 10 G_3




Fig. 11 G_4




Fig. 15 G_8




Fig. 12 G_5




Fig. 13 G_6




Fig. 14 G_7

7. CONCLUSIONS

Design methods based on knowledge of only one point on the Nyquist curve, like the Ziegler-Nichols method and specifications on phase and amplitude margins, have the advantage of being simple to use. Ziegler and Nichols also proposed a simple method to identify one point on the Nyquist curve.

In Hägglund and Åström (1984), the limitations of design methods based on knowledge of only one point on the Nyquist curve was demonstrated. The dominant pole design method, which is based on the knowledge of two points on the Nyquist curve, is a method to approximately position those poles which have a dominant influence on the transient behaviour of the system. In Hägglund and Åström (1984) and in this report, this method is shown avoid the problems associated with the simpler methods mentioned above, and to manage to control many models of processes which are common in the process industry.

The dominant pole design method is primarily intended to be used combined with the autotuning method presented in Åström and Hägglund (1984b). This enables an automatic determination of the two points on the Nyquist curve.

8. REFERENCES

- Åström, K. J. and T. Hägglund (1983): Automatic Tuning of Simple Regulators for Phase and Amplitude Margins Specifications. Proceedings IFAC Workshop on Adaptive Systems in Control and Signal Processing. San Francisco.
- Åström, K. J. and T. Hägglund (1984a): Automatic Tuning of Simple Regulators. Proceedings IFAC 9th World Congress. Budapest.
- Åström, K. J. and T. Hägglund (1984b): Automatic Tuning of Simple Regulators with Specifications on Phase and Amplitude Margins. *Automatica* **20**, 645-651.
- Elgerd, O. I. and W. C. Stephens (1959): Effect of Closed-Loop Transfer Function Pole and Zero Locations on the Transient Response of Linear Control Systems. *Applications and Industry* **42**, 121-127.
- Hägglund, T and K.J. Åström (1984): A new method for design of PID regulators. Report TFRT-7273. Dept of Automatic Control, Lund Institute of Technology, Sweden.
- Horowitz, I (1963): *Synthesis of Feedback Systems*. Academic Press, New York.
- Mulligan, L H (1949): The Effect of Pole and Zero Locations on the Transient Response of Linear Dynamic Systems. *Proceedings, Institute of Radio Engineers* **37**, 516-529.
- Truxal, J (1955): *Automatic Feedback Control System Synthesis*. McGraw-Hill, New York.
- Ziegler, J G and Nichols, N B (1943): Optimum settings for automatic controllers. *Trans. ASME* **65**, 433-444.