



LUND UNIVERSITY

Properties of the Equations Describing a Tank Reactor

Åström, Karl Johan

1972

Document Version:

Publisher's PDF, also known as Version of record

[Link to publication](#)

Citation for published version (APA):

Åström, K. J. (1972). *Properties of the Equations Describing a Tank Reactor*. (Research Reports TFRT-3046). Department of Automatic Control, Lund Institute of Technology (LTH).

Total number of authors:

1

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

PROPERTIES OF THE
EQUATIONS DESCRIBING
A TANK REACTOR

K. J. ÅSTRÖM

Report 7224 (B) September 1972
Lund Institute of Technology
Division of Automatic Control

PROPERTIES OF THE EQUATIONS DESCRIBING A TANK REACTOR

by

K.J. Åström

Contents

Abstract

1. INTRODUCTION

 Isothermic Reactors

 Adiabatic Reactors

 Reactors with cooling

2. BATCH REACTORS

3. THE STIRRED TANK REACTOR

4. LINEARIZED ANALYSIS

5. ACKNOWLEDGEMENT

6. REFERENCES

This work has been supported by the Swedish Board for Technical Development under the Contract 71-50/U33.

PROPERTIES OF THE EQUATIONS DESCRIBING A TANK REACTOR

by

K.J. Åström

Abstract

Mathematical models describing the dynamics of tank reactors are well-known in literature. The equations are strongly nonlinear which makes the analysis hard. It has been shown for batch reactors that there exist invariants which make it possible to reduce the order of the equations. Based on linearized analysis it has also been shown that the equations for tank reactors have asymptotic invariants. The purpose of this note is to show that the nonlinear equations for tank reactors have asymptotic invariants. A simplified derivation of the results for the linearized equations is also given.

1. INTRODUCTION

Consider a tank reactor where n constituents react in m reactions. Let c be a vector whose i :th component is the concentration of the i :th constituent in the reactor, let r be a vector whose i :th component is the rate of the i :th reaction, let α be the ratio of volumetric flow and reactor volume. At the transpose of the matrix. It is assumed that the columns of A are linearly independent. The mass balance for the reactor can then be written as

$$\frac{dc}{dt} = \alpha(c_f - c) + A r(c, T) \quad (1.1)$$

where the vector c_f denotes the concentration of the feed. Notice that the reaction rate r depends on the concentration and on temperature. The temperature can be determined from an enthalpy balance. This may take different forms depending on the practical arrangement of the reactor. Three cases will be considered i.e. isothermic, adiabatic and reactors with cooling.

Isothermic Reactors

In the isothermic case the temperature T is constant and the reactor is described by (1.1).

$$\frac{dc}{dt} = \alpha(c_f - c) + A r(c) \quad (1.2)$$

Adiabatic Reactors

In the adiabatic case the enthalpy balance becomes

$$\frac{dh}{dt} = \alpha(h_f - h) + a r(c, T) \quad (1.3)$$

where h_f is the enthalpy of the feed, a is a row vector whose i :th component denotes the enthalpy per mole generated in the i :th reaction and $r(c, T)$ is the reaction rate as before. Since T is a function of h we thus find that the reaction rate is given by

$$r = r_1(c, h) = r(c, T(h)) \quad (1.4)$$

Introducing the vector

$$x = \begin{bmatrix} c \\ h \end{bmatrix} \quad (1.5)$$

and the matrix

$$\tilde{A} = \begin{bmatrix} A \\ a \end{bmatrix} \quad (1.6)$$

the equation for an adiabatic reactor can thus be written as

$$\frac{dx}{dt} = \alpha(x_f - x) + \tilde{A} r(x) \quad (1.7)$$

which is identical in form to (1.4).

We thus find that (1.7) describes both the adiabatic and the isothermic cases.

The matrix A has m columns in both cases. Notice that the dimension k of the state vector of (1.7) equals n in the isothermic case and $n+1$ in the adiabatic case.

Reactors with cooling

A complete description of a reactor with cooling requires an enthalpy balance. The nice structure of the equations is then lost and it is difficult to make general statements as can be done for isothermic and adiabatic reactors.

2. BATCH REACTORS

First consider batch reactors i.e. $\alpha=0$. The equation (5) then reduces to

$$\frac{dx}{dt} = Ar(x) \quad (2.1)$$

Let V be the subspace of \mathbb{R}^k that is spanned by the columns of A and U its orthogonal complement which is of dimension $k-m$. Any vector $x \in X$ can then be rewritten as

$$x = u + Av \quad (2.2)$$

where $v \in \mathbb{R}^m$ and

$$u^T A = 0 \quad (2.3)$$

Introducing (2.2) into (1.5) gives

$$\frac{dx}{dt} = \frac{du}{dt} + A \frac{dv}{dt} = Ar(u+Av)$$

Projecting this equation on U and V gives

$$\frac{du}{dt} = 0 \quad (2.4)$$

$$\frac{dv}{dt} = r(u+Av) \quad (2.5)$$

We thus find that

$$u(t) = u_0 = \text{constant} \quad (2.6)$$

which means that there are $k-m$ invariants, ($n-m$ in the isothermic case and $n-m+1$ in the adiabatic case) and that the analysis of the batch reactor can be reduced to the analysis of the equation

$$\frac{dv}{dt} = r(u_0 + Av) \quad (2.7)$$

where $v \in \mathbb{R}^m$.

Using the explicit form of the projection operator the reaction invariants can also be written as

$$\left[I - A(A^T A)^{-1} A^T \right] \left[x(t) - x(0) \right] = 0 \quad (2.8)$$

3. THE STIRRED TANK REACTOR

Now consider the general case i.e. $\alpha \neq 0$. Proceeding as before to partition the state space into U and V and introduce (2.2) into (1.5) we get

$$\frac{dx}{dt} = \frac{du}{dt} + A \frac{dv}{dt} = \alpha(u_f + Av_f - u - Av) + Ar(u + Av) \quad (3.1)$$

Projecting this equation on U and V respectively and we find

$$\frac{du}{dt} = \alpha(u_f - u) \quad (3.2)$$

$$\frac{dv}{dt} = \alpha(v_f - v) + r(u + Av) \quad (3.3)$$

The reactor is thus described by the equations (3.2) and (3.3). In this case there are no true invariants. Notice however that the equation (3.2) can be solved explicitly

$$u(t) = u_f + u_0 \cdot e^{-\alpha t} \quad (3.4)$$

In this case there are no true invariants since
It follows from (3.4) that

$$\lim_{t \rightarrow \infty} u(t) = u_f \quad (3.5)$$

Since $\dim U = k-m$ we thus find that there are $k-m$ asymptotic invariants. In analogy with (2.8) these asymptotic invariants can be expressed as

$$\lim_{t \rightarrow \infty} \left[I - A(A^T A)^{-1} A^T \right] \left[x(t) - x(0) \right] = 0 \quad (3.6)$$

Introducing (3.5) into (3.3) we find

$$\frac{dv}{dt} = \alpha(v_f - v) + r(u_f + u_0 \exp(-\alpha t)) + Av \quad (3.7)$$

and we find that the reactor can be described by an equation of dimension m . Notice that (3.7) is not autonomous. However when t goes to infinity the equation (3.7) will converge to

$$\frac{dv}{dt} = \alpha(v_f - v) + r(u_f + Av) \quad (3.8)$$

If $u(t) = u_f$ the space U is an uncontrollable subspace of (3.1) if the feed is considered as the control variable. This means that if $u(t) = u_f$, the reactor will be described by (3.8) even if the feed is changed.

Also notice that if the input composition x_f is changed in such a way that it remains in the subspace spanned by the columns of A , $u(t)$ remains constant.

4. LINEARIZED ANALYSIS

Assuming small perturbations around a reference solution we find that the perturbations δx satisfies the equation

$$\frac{d}{dt} \delta x = -\alpha \delta x + (A \ B) \delta x = (-\alpha I + A \ B) \delta x \quad (4.1)$$

where

$$B = r_x$$

and r_x denotes the matrix of partial derivatives of r evaluated of the reference solution. Similarly linearization of (3.6) around a reference solution with $u = u_f$ gives

$$\frac{d}{dt} \delta v = -\alpha \delta v + BA \delta v = (-\alpha I + BA) \delta v \quad (4.2)$$

The character of the solutions of (4.1) and (4.2) in the neighbourhood of the reference solutions are thus given by the matrices AB and BA. Notice that A is an $k \times m$ matrix ($k \geq m$) and B is an $m \times k$ matrix.

The relation between the eigenvectors of the matrices AB and BA will now be explored.

Let e be an eigenvector of AB corresponding to the eigenvalue λ then

$$AB e = \lambda e \quad (4.3)$$

Multiplication of this equation by B from the left gives

$$BA(Be) = B\lambda e = \lambda(Be)$$

Hence if e belongs to the subspace spanned by the rows of B, Be is nonzero and we thus find that Be is an eigenvector of BA corresponding to the eigenvalue λ . If B is of rank m there are then m eigenvectors such that Be is not zero and we thus find that at least in the case of distinct eigenvalues all eigenvalues of BA are among those of AB and furthermore that the eigenvectors are simply related.

5. ACKNOWLEDGEMENT

I became aware of this problem when being opponent on Dr. Fjelds dissertation.

6. REFERENCES

- [1] Fjeld, M.: Stability and Control of Periodic Processes, Thesis, Norges Tekniske Høgskole, Universitetet i Trondheim, Institutt for Reguleringssteknikk, April 1971.
- [2] Asbjørnsen, O.A.: Reaction Invariants in the Control of Continuous Chemical Reactors, Chem. Eng. Sci. 27(1972) 709-717.