

Åström, Karl Johan; Bell, Rodney D.

1988

Document Version: Publisher's PDF, also known as Version of record

Link to publication

Citation for published version (APA): Aström, K. J., & Bell, R. D. (1988). Simple Drum-Boiler Models. (Technical Reports TFRT-7402). Department of Automatic Control, Lund Institute of Technology (LTH).

Total number of authors:

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

• Users may download and print one copy of any publication from the public portal for the purpose of private study

- You may not further distribute the material or use it for any profit-making activity or commercial gain
 You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: https://creativecommons.org/licenses/

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

Download date: 18. Dec. 2025

CODEN: LUTFD2/(TFRT-7402)/1-34/(1988)

Simple Drum-Boiler Models

K J Åström R D Bell

Department of Automatic Control Lund Institute of Technology October 1988

Department of Automatic Control Lund Institute of Technology P.O. Box 118 S-221 00 Lund Sweden		Document name Report	
		Date of issue	
		October 1988	
		Document Number	
		CODEN: LUTFD2/(TFR	T-7402)/1-34/(1988)
Author(s)		Supervisor	
K J Åström and R D Be	41		
		Sponsoring organisation	
Title and subtitle			
Simple Drum-Boiler Models.			
Abstract			
This paper describes a simple nonlinear models for a drum-boiler. The models are derived from first principles.			
They can be characterized by a few physical parameters that are easily obtained from construction data. The			
models also require steam tables for a limited operating range, which can be approximated by polynomials.			
The models have been validated against experimental data. A complete simulation program is provided.			
Key words			
New World's			
Classification system and/or index terms (if any)			
Supplementary bibliographical information			
ISSN and key title			ISBN
Language	Number of pages	Recipient's notes	
English	34		
Security classification			

The report may be ordered from the Department of Automatic Control or borrowed through the University Library 2, Box 1010, S-221 03 Lund, Sweden, Telex: 33248 lubbis lund.

Paper presented on IFAC Symposium on Power Systems Modelling and Control Applications, Brussels, Belgium, September 5-8, 1988.

Simple Drum-Boiler Models

K J Åström

Department of Automatic Control

Lund Institute of Technology

S-221 00 Lund

Sweden

Abstract

This paper describes a simple nonlinear models for a drumboiler. The models are derived from first principles. They can be characterized by a few physical parameters that are easily obtained from construction data. The models also require steam tables for a limited operating range, which can be approximated by polynomials. The models have been validated against experimental data. A complete simulation program is provided.

1. Introduction

There are many models of drum-boilers in the literature. See the reference list. The models described in this paper are derived from first principles. They are characterized by a few parameters only which can be obtained from first principles. The models are validated by comparison with extensive plant data.

A key feature of a drum-boiler is that there is a very efficient energy and mass transfer between all parts that are in contact with the steam. The mechanism responsible for the heat transfer is boiling and condensation. A consequence of this is that it is a very good approximation to assume that all water steam and metal is in thermal equilibrium. This means that the total energy can be represented by a global energy balance. The validity of this approximation has been shown by many modeling exercises.

The paper is organized as follows. A first order model is presented in Section 2. This model is obtained from a global energy balance for the total plant. The model has one state variable which is chosen as the drum pressure. This model has the same structure as the model presented in Astrom and Eklund (1972). The parameters are, however, obtained from first principles. To model the drum water level it is necessary to account for the shrink and swell phenomena. This is done in Section 3. A third order model is obtained. This model has drum pressure, water volume and steam quality in the risers as state variables. The model exhibits a complex behaviour in spite of being of low order. Simulation of step responses are presented in Section 4.

2. A First Order Model

Because of the efficient heat and mass transfer due to boiling and condensation all parts of the system which are in contact with the steam will be in thermal equilibria. It is therefore natural to describe the plant with global mass and energy balances as was done in Astrom and Eklund (1972). The global energy balance can be written as

$$\frac{d}{dt}\left[\varrho_{s}h_{s}V_{st} + \varrho_{w}h_{w}V_{wt} + mc_{p}T\right] = P + q_{fw}h_{fw} - q_{s}h_{s} \quad (1)$$

where ϱ denotes specific density, h enthalphy, V volume and q mass flow. The indices s, w and fw refers to steam, water and feedwater respectively. The total mass of the metal tubes is m, the specific heat is c_p and the average metal temperature is T.

R D Bell

School of Mathematics and Physics Macquarie University North Ryde New South Wales 2213 Australia

The input power from the fuel is denoted by P. The total steam volume is given by

$$V_{st} = V_{drum} - V_w + a_m V_r \tag{2}$$

where V_{drum} is the drum volume, V_w the volume of water in the drum, V_r the riser volume and a_m the average steam-water volume ratio. The total water volume is

$$V_{wt} = V_w + V_{dc} + (1 - a_m)V_r \tag{3}$$

The right hand side of equation (1) represents the energy flow to the system from fuel and feedwater and the energy flow from the system via the steam. Since all parts are in thermal equilibria the state of the system can be represented by one variable which we choose as the steam pressure. Using steam tables the variables ϱ_s , ϱ_w , h_s and h_w can then be expressed as functions of steam pressure. Similarly T can be expressed as a function of pressure by assuming that T is equal to the saturation temperature of steam which corresponds to p.

This model represents the dynamics due to input power well. When the feedwater flow or the steam flow is changed it is, however, necessary to also take into account that the water and steam masses are also changing. This can be accounted for with a global massbalance.

$$\frac{d}{dt}\left[\varrho_{s}V_{st} + \varrho_{w}V_{wt}\right] = q_{fw} - q_{s} \tag{4}$$

The dynamics which describe how the drum pressure is influenced by input power, feedwater flow and steam flow is well captured by equations (1) and (4).

The derivative of the total water volume (dV_{wt}/dt) can be eliminated between equations (1) and (4). Multiplication of (4) by h_w and subtracting from (1) gives

$$h_{c}\frac{d}{dt}(\varrho_{s}V_{st}) + \left[\varrho_{s}V_{st}\frac{dh_{s}}{dt} + \varrho_{w}V_{wt}\frac{dh_{w}}{dt} + mc_{p}\frac{dT}{dt}\right]$$

$$= P - q_{fw}(h_{w} - h_{fw}) - q_{s}h_{c}$$
(5)

The condensation enthalpy $h_c = h_s - h_w$ has also been introduced. If the boiler is provided with a good level control system the total water volume (V_{ut}) and the total steam volume (V_{st}) do not change much. Equation (5) can then be simplified to

$$e_{11}\frac{dp}{dt} = P - q_{fw}(h_w - h_{fw}) - q_s h_c$$
 (6)

where

$$e_{11} = h_e V_{st} \frac{d\varrho_s}{dp} + \varrho_s V_{st} \frac{dh_s}{dp} + \varrho_w V_{wt} \frac{dh_w}{dp} + mc_p \frac{dT_s}{dp}$$

Apart from steam table data it is thus sufficient to know total steam and water volumes and total metal mass. The model (6) is identical to the model in Astrom and Eklund (1972). Notice however that in this case the parameters are obtained from construction data. Also notice that the term

$$q_{\rm c} = -\frac{1}{h_{\rm c}} \left[\varrho_{\rm s} V_{\rm st} \frac{dh_{\rm s}}{dt} + \varrho_{\rm w} V_{\rm wt} \frac{dh_{\rm w}}{dt} + m c_{\rm p} \frac{dT_{\rm s}}{dt} \right] \label{eq:qc}$$

can be interpreted as the total condensation flow. It is observed that the terms dh_s/dp and dh_w/dp are key quantities in predicting the energy and mass transfer between steam and water. These terms also appeared in the drum-boiler model of Morton and Price (1977).

3. Shrink and Swell

For some control tasks e.g. drum level control it is necessary to model the dynamics of the drum level. This is more difficult because of the shrink and swell effect. To describe this it is necessary to account for the distribution of steam and water and the transfer of mass and energy between steam and water.

The steam-water distribution varies along the risers. Partial differential equations are needed to describe this properly. To keep a finite dimensional model we will assume that the shape of the distribution is known. The assumed shape is based on solving the partial differential equations in the steady state. This gives a linear distribution of the steam-water mass ratio along the risers. We will therefore assume that the ratio varies

$$x(\xi) = x_r \xi \quad 0 \le \xi \le 1 \tag{7}$$

where ξ is a normalized length coordinate along the risers and x_τ is the steam-water mass ratio at the riser outlet. The transfer of mass and energy between steam and water by condensation and evaporation is a key element in the modelling. When modelling steam and water separately the transfer must be accounted for explicitly. This can be avoided by writing joint balance equations for water and steam. The global mass balance for the riser section is

$$\frac{d}{dt}(\varrho_s a_m V_r) + \frac{d}{dt}(\varrho_w (1 - a_m) V_r) = q_{dc} - q_r \tag{8}$$

where q_r is the total mass flow out of the risers. The global energy balance for the riser section is

$$\frac{d}{dt}(\varrho_{s}h_{s}a_{m}V_{r}) + \frac{d}{dt}(\varrho_{w}h_{w}(1 - a_{m})V_{r}) =
P + q_{dc}h_{w} - x_{r}q_{r}h_{s} - (1 - x_{r})q_{r}h_{w} =
P + q_{dc}h_{w} - x_{r}q_{r}h_{c} - q_{r}h_{w}$$
(9)

The flow out of the risers (q_r) can be eliminated by multiplying equation (8) by $-(h_w+x_rh_c)$ and adding to equation (9). Hence

$$\begin{aligned} &\frac{d}{dt}(\varrho_s h_s a_m V_r) - (h_w + x_r h_c) \frac{d}{dt}(\varrho_s a_m V_r) \\ &+ \frac{d}{dt}(\varrho_w h_w (1 - a_m) V_r) - (h_w + x_r h_c) \\ &\frac{d}{dt}(\varrho_w (1 - a_m) V_r) = P - x_r h_c q_{dc} \end{aligned}$$

This can be simplified to

$$h_c(1-x_r)\frac{d}{dt}(\varrho_s a_m V_r) + \varrho_w (1-a_m) V_r \frac{dh_w}{dt} - x_r h_c \frac{d}{dt}(\varrho_w (1-a_m) V_r) + \varrho_s a_m V_r \frac{dh_s}{dt} = P - x_r h_c q_{dc}$$

$$(10)$$

Drum Level

To calculate the drum level it is necessary to know the average steam-water volume ratio in the risers (a_m) . We have

$$x = \frac{\varrho_s a}{\varrho_s a + \varrho_w (1 - x)}$$

Solving this equation for a we get

$$a = a(x) = \frac{\rho_w x}{\rho_s + (\rho_w - \rho_s)x}$$

Assume that the steam-water mass ratio is linear along the riser as expressed by equation (7). The average steam-water volume ratio in the risers is

$$a_{m} = \int_{0}^{1} a(x_{r}\xi)d\xi = \frac{1}{x_{r}} \int_{0}^{1} a(x_{r}\xi)d(x_{r}\xi)$$

$$= \frac{1}{x_{r}} \int_{0}^{x_{r}} a(x)dx$$

$$= \frac{\ell_{w}}{\ell_{w} - \ell_{s}} \left[1 - \frac{\ell_{s}}{(\ell_{w} - \ell_{s})x_{r}} \ln \left(1 + \frac{\ell_{w} - \ell_{s}}{\ell_{s}} x_{r} \right) \right]$$
(11)

We can now obtain the following equation for the drum level

$$\ell = \frac{V_w + a_m V_r}{A} \tag{12}$$

where A is the wet surface of the drum. This equation tells that the drum level is composed of two terms, the total amount of water in the drum, and the displacement due to changes of the steam-water ratio in the risers. The model has the same basic form as the water level model in Bell and Astrom (1979). This model was, however, developed heuristically and not from first principles.

Downcomer Flow

The flow through the downcomers (q_{de}) can be obtained from a momentum balance. In natural circulation boilers the flow is driven by the difference between the densities of water and steam. A momentum balance gives

$$a_m V_r(\varrho_w - \varrho_s) = \frac{1}{2} k \, q_{dc}^2 \tag{13}$$

where k is a friction coefficient. The riser flow q_r can be calculated from equation (8). We get

$$q_r = q_{dc} - \frac{d}{dt} \left(\varrho_s \alpha_m V_r \right) - \frac{d}{dt} \left(\varrho_w (1 - a_m) V_r \right) \tag{14}$$

4. Simulations

The equations derived in Section 3 will now be summarized. The state equations are given by (1), (4) and (8). The state variables are chosen as drum pressure p, water volume in drum V_w and average steam quality at riser outlet x_r . Equation (1), (4) and (8) can then be written as

$$\begin{cases} e_{11} \frac{dp}{dt} + e_{12} \frac{dV_w}{dt} + e_{13} \frac{dx_r}{dt} = P + q_{fw} h_{fw} - q_s h_s \\ e_{21} \frac{dp}{dt} + e_{22} \frac{dV_w}{dt} + e_{23} \frac{dx_r}{dt} = q_{fw} - q_s \\ e_{31} \frac{dp}{dt} + e_{33} \frac{dx_r}{dt} = P - q_{dc} x_r h_c \end{cases}$$
(15)

where

$$e_{11} = \left(\frac{d\varrho_s}{dp}h_s + \varrho_s \frac{dh_s}{dp}\right) V_{st} + \left(\frac{d\varrho_w}{dp}h_w + \varrho_w \frac{dh_w}{dp}\right) V_{wt} +$$

$$mc_p \frac{dT_s}{dp}$$

$$e_{12} = \varrho_w h_w - \varrho_s h_s$$

$$e_{13} = (\varrho_s h_s - \theta_w h_w) V_r \frac{da_m}{dx_r}$$

$$e_{21} = \frac{d\varrho_s}{dp} V_{st} + \frac{d\varrho_w}{dp} V_{wt}$$

$$e_{22} = \varrho_w - \varrho_s$$
(16)

$$\begin{split} e_{23} &= \left(\varrho_s - \varrho_w\right) V_r \frac{da_m}{dx_r} \\ e_{31} &= \left[\left(1 - x_r\right) h_c \frac{d\varrho_s}{dp} + \varrho_s \frac{dh_s}{dp} \right] a_m V_r \\ &+ \left[\varrho_w \frac{dh_w}{dp} - x_r h_c \frac{d\varrho_w}{dp} \right] (1 - a_m) V_r \end{split}$$

$$e_{33} = \left[(1 - x_r) \varrho_s + x_r \varrho_w \right] h_c V_r \frac{da_m}{dx_-}$$

To execute the simulation equation (15) has to be solved for the derivatives of the state variables. The right hand side of (15) contain input variables P, q_{fw} and q_{τ} , and functions of the state variables. Notice that downcomer flow q_{dc} is given by equation (13). A detailed description of the simulation is given in the code in the Appendix.

Parameters

The model is characterized by the variables

friction coefficient

 $egin{array}{ll} V_{drum} & ext{drum volume} \ V_r & ext{riser volume} \ V_{dc} & ext{downcomer volume} \ m & ext{total metal mass} \ c_p & ext{specific heat of metal} \ \end{array}$

and the functions $\varrho_s(p)$, $\varrho_w(p)$, $h_s(p)$, $h_w(p)$, $T_s(p)$, $h_{fw}(p)$ which are obtained from steam tables. Quadratic approximations to the steam tables are given in the program listing in the Appendix.

Equilibrium Conditions

Equilibrium conditions are obtained from (15). Hence

$$q_{fw} = q_s \tag{17}$$

$$P = q_s(h_s - h_{fw}) \tag{18}$$

$$P = q_{dc}x_r h_c \tag{19}$$

The equilibrium value of the drum pressure can be determined from equation (18) since h_s and h_{fw} depend on the pressure.

Dynamic Response


Responses to steps in fuel flow and steam flow are given in Figures 1 and Figure 2. The simulations illustrate the dynamic features that are captured by the model. Figure 1 shows the response to a step change in fuel flow. The pressure responds like a pure integrator. The total amount of water in the drum

increases because steam is generated in the risers. The total amount of steam in the risers increases because of the increased steam generation. The steam quality in volume ratios increases initially but it will later decrease because of the compression effect.

The drum level increases rapidly at first but the rate of increase decreases. The downcomer flow matches the steam fraction volume ratio. There is an instantaneous increase of the riser flow at the beginning of the step. The riser flow will then decrease at the same rate as the downcomer flow. Figure 2 shows the response to a step change in steam flow. The global effect is that the pressure and the volume will respond like integrators. There will, however, be a swell effect because of the initial evaporation of steam.

5. Conclusions

This paper has presented simple models for a drum boiler system. The models capture the major dynamical behaviour. They are derived from first principles and require only a few physical parameters that are easily obtained from construction data and steam tables. The behaviour has been shown by simulating step responses to fuel and steam flow changes. Reasonable results are obtained even for the difficult problems of predicting circulation flow and drum water level shrink and swell. The model can easily be augmented by equations for turbine and electrical output given in Astrōm and Eklund (1972, 1975) or Bell and Astrōm (1979) to produce a simple model for a complete boiler-turbine alternator system. A strong feature is that the model capture the essence of the steam generation in a heated pipe. It has also been used successfully to model steam generation in a nuclear plant. It can also be adapted to model once-through boilers.







Figure 1. Responses to a step in fuel flow.






Figure 2. Response to a step in steam flow.

6. References

B-0405

Anderson, P.M. and S. Nanakorn (1974): "An analysis and comparison of certain low-order boiler models," ISA 1974.

ASTROM, K.J. and K. EKLUND (1972): "A simplified non-linear model of a drum-boiler turbine unit," Int. J. Control, 16, 145-169.

ASTROM, K.J. and K. EKLUND (1975): "A simple non-linear drum-boiler model," Int. J. Control, 22, 739-740.

Bell, R.D. and K.B. Lee (1974): "Linear models for Liddell Power Station," Report, School of Electrical Engineering, University of N.S.W. Australia.

Bell, R.D., N.W. Rees and K.B. Lee (1977): "Models of large boiler-turbine plant," IFAC Symp. on Auto. Cont. & Protection of Electric Power Systems, 469-475.

Bell, R.D., N.W. Rees and T. Done (1978): "Nonlinear and linear models of a 500 MW boiler-turbine system," Report, School of Electrical Engineering, University of N.S.W. Australia.

Bell, R.D. and K.J. Astrom (1979): "A low order nonlinear dynamic model for drum-boiler-turbine alternator units," TFRT 7162, Department of Automatic Control, Lund Institute of Technology, Lund, Sweden.

Bell, R.D. and K.J. Astrom (1987): "Simplified models of boiler-turbine units," Report, Department of Automatic Control, Lund Institute of Technology, Lund, Sweden.

Berkowitz, L.D. (Ed.) (1974): Proceedings of the seminar on boiler modeling, The Mitre Corp, Bedford, MA.

BLOETHE, W.G. and P.M. Anderson, "Application of a low-order boiler model to transient stability studies," IEEE Trans. Aut. Contr..

Burger, W.A. (1978): "Evaluation and comparison of three low order models of drum boiler steam power plants," M.Sc. thesis, Massachusetts Institute of Technology, MA, USA.

CHIEN, K.L., E.I. ERGIN, C. LING and A. LEE (1958): "Dynamic analysis of a boiler," Trans. ASME, 80.

EKLUND, K. (1968): "Linear mathematical models of the drum-downcomer-riser loop of a drum-boiler," TFRT 3005, Department of Automatic Control, Lund Institute of Technology, Lund, Sweden. EKLUND, K. (1971): "Linear drum-boiler-turbine models," TFRT 1001, Department of Automatic Control, Lund Institute of Technology, Lund, Sweden.

HERGET, C.J. and C.U. PARK (1973): "Parameter identification and verification of low-order boiler models," IEEE Trans Aut. Contr..

IEEE COMMITTEE, "Dynamic models for steam- and hydroturbines in power system studies," IEEE Trans. Aut. Contr..

KWAN, H.W. and J.H. ANDERSSON (1970): "A mathematical model of a 200 MW boiler," Int. Journal of Control, 12, 977-998.

McDonald, J. P., G.H. Kwatny and J.H. Spare (1971): "A nonlinear model for reheat boiler-turbine generation systems," Proc. JACC, 227-236.

MORTON, A.J. and P.H. PRICE (1977): "The controllability of steam output, pressure and water level in drum boilers," Proc. I. Mech. Eng., 75-84.

NICHOLSON, P.T. (1983): "Boiler-turbine modelling and simulation," M.E. thesis, University of N.S.W., Australia.

REES, N.W., R.D. Bell and K.B. Lee (1974): "Modelling and control studies of a 500 MW generating plant," Report, School of Electrical Engineering, University of N.S.W., Australia.

THOMPSON, F.T. (1964): "A dynamic model for control of a drum type boiler system," Ph.D. Thesis, University of Pittsburg.

Appendix

CONTINUOUS SYSTEM DRUM
"Nonlinear third order model for drum-downcomerriser
"Author K J Astrom 870805

INPUT pow qfw tfw qs OUTPUT dl am STATE p Vw xr DER dp dVw dxr

```
"pow
            Power from fuel
                                              [WW]
                                                                "Circulation flow
   "qfw
            Feedwater flow
                                               [kg/s]
                                                                s1 = 2*(rw-rs)*Vr*am/k
   "tfw
           Feedwater temperature
                                               [deg C]
                                                                qdc = sqrt(s1)
   "qв
            Steam flow
                                              [kg/s]
                                                                qr=qdc-(am*drsdp+(1-am)*drwdp)*Vr*dp+(rw-rs)
                                                                *Vr*damdx*dxr
   "dl
           Drum level
                                               [m]
   "am
           Steam quality volume ratio
                                                                "Total condensation flow
   "qc
           Condensate flow (total)
                                               [kg/s]
                                                                qc = (rs*Vst*dhsdp+rw*Vwt*dhwdp)*dp/hc
   "qcr
           Condensate flow (risers)
                                              [kg/s]
                                                                "Condensation flow in risers
   "P
           Drum pressure
                                               [MPa]
                                                                qcr = (rs*am*Vr*dhsdp+rw*(1-am)*Vr*dhsdp)*dp/hc
   "Vw
           Drum water volume
                                               [m*m*m]
   "xr
           Steam quality at riser outlet
                                                                "Equations for derivatives of state variables
                                                                Vst = Vdrum - Vw + am + Vr
   "Properties of steam and water in saturated state
                                                                Vwt = Vw + Vdc + (1-am)*Vr
                                                                e11 = Vst*(hs*drsdp rs*dhsdp)+Vwt*
   hs = a01+(a11+a21*(p-10))*(p-10)
                                                                (hw*drwdp+rw*dhwdp)
   dhsdp = a11+2*a21*(p-10)
                                                                e12 * hw*rw-hs*rs
   a01: 2.728E6
                                                                e13 = (hs*rs-hw*rw)*Vr*damdx
   a11: -1.792E4
                                                                b1 = pow * 1e6 + qfw * hfw - qs * hs
   a21: -924.0
                                                                e21 = Vst*drsdp+Vwt*drwdp
                                                                e22 = rw-rs
   rs = a02+(a12+a22+(p-10))*(p-10)
                                                                e23 = (rs-rw)*Vr*damdx
   drsdp = a12+2*a22*(p-10)
                                                                b2 = qfw-qs
   a02: 55.43
                                                                e31 = ((1-xr)*hc*drsdp+rs*dhsdp)*am*Vr+
   a12: 7.136
                                                                (rw*dhwdp-xr*hc*drwdp)*(1-am)*Vr
   a22: 0.224
                                                                e32 = 0
                                                                e33 = ((1-xr)*rs+xr*rw)*hc*Vr*damdx
   hw = a03+(a13+a23*(p-10))*(p-10)
                                                                b3 = pow*1e6-qdc*xr*hc
   dhwdp = a13+2*a23*(p-10)
   a03: 1.408E6
                                                                "Solve linear equation for derivatives of state
   a13: 4.565E4
                                                                vector pi = e21/e11
   a23: -1010.0
                                                                e221 = e22-e12*p1
                                                                e231 = e23-e13*p1
   rw = a04+(a14+a24*(p-10))*(p-10)
                                                                b21 = b2-b1*p1
 \sqrt{\frac{1}{2}} drwdp = a14+2*a24*(p-10)
  a04: 691.35
                                                                p2 = e31/e11
   a14: -1.867
                                                                e321 = -e12*p2
   a24: 0.081
                                                                e331 = e33-e13*p2
                                                                b31 = b3-b1*p2
   ts = a05+(a15+a25*(p-10))*(p-10)
   dtsdp = a15+2*a25*(p-10)
                                                                p3 = e321/e221
   a05: 311.0
                                                                e332 = e331-e231*p3
a15: 7.822
a25: -0.32
                                                                b32 = b31-b21*p3
"Properties of water in subcritical state
                                                                dxr = b32/e332
                                                                dVw = (b21-e231*dxr)/e221
                                                                dp = (b1-e12*dVw-e13*dxr)/e11
"hd = hw+(a06+a16*(p-10))*(td-ts)
   "dhddp = dhwdp+a16*(td-ts)-(a06+a16*(p-10))*dtsdp
                                                                "Parameters
   "cp = a06+a16*(p-10)
                                                                adrum: 20
  a06: 5900
                                                                vdrum: 40
a16: 250
                                                                vr: 37
                                                                vdc: 19
  "rd = rw+(a07+a17*(p-10))*(td-ts)
                                                                k: 0.01
   "drddp = drwdp+a17*(td-ts)-(a07+a17*(p-10))*dtsdp
   "drddt = a07+a17*(p-10)
                                                                "Initials
   "a07: 2.4
                                                               p: 7.576
  "a17: 0.2
                                                                Vw:13.521
                                                                xr:0.091263
  hfw = hw+(a06+a16*(p-10))*(tfw-ts)
  hc = hs-hw
  hr = xr*hs+(1-xr)*hw
  "Drum level
  lw=Vw/adrum
  lr=am * Vr/adrum
  dl = lr+lw
  "Average steam quality volume ratio
  s2 = rs/(xr*(rv-rs))
```

83 = 1 + xr*(ru/rs-1)

am = rw/(rw-rs)*(1-s2*ln(s3))

damdx = rw*s2*(ln(s3)/(xr*(rw-rs))-1/s3/rs)

K. J. Åström

Department of Automatic Control

Lund Institute of Technology

S-221 00 Lund

Sweden

R. D. Bell
School of Mathematics and Physics
Macquarie University
North Ryde New South Wales 2213
Australia

- 1. Introduction
- 2. First Order Model
- 3. Shrink and Swell
- 4. Simulations
- 5. Experiments
- 6. Conclusions

INTRODUCTION

Motivation

Simple physics based models for system studies

Experimental verification Industrial collaboration with Sydkraft AB Malmö Sweden

Progress

Slow painstaking

Eklund 1968

Åström Eklund 1972, 1975

Bell and Åström 1979

Bell and Åström 1987

1. Introduction

2. First Order Model

- 3. Shrink and Swell
- 4. Simulations
- 5. Experiments
- 6. Conclusions

Global Energy Balance

$$\frac{d}{dt} \left[\rho_s h_s V_{st} + \rho_w h_w V_{wt} + m c_p T \right]
= P + q_{fw} h_{fw} - q_s h_s$$
(1)

Total Steam Volume

$$V_{st} = V_{drum} - V_w + a_m V_r \tag{2}$$

Total Water Volume

$$V_{wt} = V_w + V_{dc} + (1 - a_m)V_r \tag{3}$$

Global Mass Balance

$$\frac{d}{dt}\left[\rho_s V_{st} + \rho_w V_{wt}\right] = q_{fw} - q_s \tag{4}$$

Eliminate dV_{wt}/dt between (1) and (4)

$$h_c \frac{d}{dt} \left(\rho_s V_{st} \right) + \left[\rho_s V_{st} \frac{dh_s}{dt} + \rho_w V_{wt} \frac{dh_w}{dt} + mc_p \frac{dT}{dt} \right]$$

$$= P - q_{fw} \left(h_w - h_{fw} \right) - q_s h_c$$
(5)

$$h_{c}\frac{d}{dt}\left(\rho_{s}V_{st}\right) + \left[\rho_{s}V_{st}\frac{dh_{s}}{dt} + \rho_{w}V_{wt}\frac{dh_{w}}{dt} + mc_{p}\frac{dT}{dt}\right]$$

$$= P - q_{fw}\left(h_{w} - h_{fw}\right) - q_{s}h_{c}$$
(5)

Rewritten as

$$e_{11}\frac{dp}{dt} = P - q_{fw}(h_w - h_{fw}) - q_s h_c$$
 (6)

$$e_{11} = h_c V_{st} \frac{d\rho_s}{dp} + \rho_s V_{st} \frac{dh_s}{dp} + \rho_w V_{wt} \frac{dh_w}{dp} + mc_p \frac{dT_s}{dp}$$

Total condensation flow

$$q_c = \frac{1}{h_c} \left[\rho_s V_{st} \frac{dh_s}{dt} + \rho_w V_{wt} \frac{dh_w}{dt} + mc_p \frac{dT_s}{dt} \right]$$

- 1. Introduction
- 2. First Order Model
- 3. Shrink and Swell
- 4. Simulations
- 5. Experiments
- 6. Conclusions

THE VOID MODEL


A distributed parameter system

Assuming a void distribution gives a lumped parameter model

The PDEs gives a steady state solution with a linear steam water mass ratio

Use static relation also for dynamics

Model explored for nuclear reactor models where elaborate simulation models are available



Mass Balance for Riser Section

$$\frac{d}{dt}\left(\rho_s a_m V_r\right) + \frac{d}{dt}\left(\rho_w (1 - a_m) V_r\right) = q_{dc} - q_r \qquad (8)$$

Energy Balance

$$\frac{d}{dt} (\rho_s h_s a_m V_r) + \frac{d}{dt} (\rho_w h_w (1 - a_m) V_r)
= P + q_{dc} h_w - x_r q_r h_s - (1 - x_r) q_r h_w
= P + q_{dc} h_w - x_r q_r h_c - q_r h_w$$
(9)

Eliminate q_r between (8) and (9)

$$\frac{d}{dt} (\rho_s h_s a_m V_r) - (h_w + x_r h_c) \frac{d}{dt} (\rho_s a_m V_r)$$

$$+ \frac{d}{dt} (\rho_w h_w (1 - a_m) V_r) - (h_w + x_r h_c)$$

$$\frac{d}{dt} (\rho_w (1 - a_m) V_r) = P - x_r h_c q_{dc}$$

Simplify to

$$h_c(1 - x_r) \frac{d}{dt} \left(\rho_s a_m V_r \right) + \rho_w \left(1 - a_m \right) V_r \frac{dh_w}{dt}$$

$$- x h_c \frac{d}{dt} \left(\rho_w (1 - a_m) V_r \right) + \rho_s a_m V_r \frac{dh_s}{dt}$$

$$= P - x_r h_c q_{dc}$$

$$(10)$$

Drum Level

Average steam-water volume ratio

$$x = \frac{\rho_s a}{\rho_s a + \rho_w (1 - x)}$$

Solving with respect to a

$$a = a(x) = \frac{\rho_w x}{\rho_s + (\rho_w - \rho_s) x}$$

Assume

$$x(\xi) = x_r \xi \qquad 0 \le \xi \le 1 \tag{11}$$

Hence

$$a_{m} = \int_{0}^{1} a(x_{r}\xi)d\xi = \frac{1}{x_{r}} \int_{0}^{1} a(x_{r}\xi)d(x_{r}\xi)$$

$$= \frac{1}{x_{r}} \int_{0}^{x_{r}} a(x)dx$$

$$= \frac{\rho_{w}}{\rho_{w} - \rho_{s}} \left[1 - \frac{\rho_{s}}{(\rho_{w} - \rho_{s})x_{r}} \ln \left(1 + \frac{\rho_{w} - \rho_{s}}{\rho_{s}} x_{r} \right) \right]$$
(11)

$$\ell = \frac{V_w + a_m V_r}{A} \tag{12}$$

Downcomer Flow

Momentum balance

$$a_m V_r(\rho_w - \rho_s) = \frac{1}{2} k \, q_{dc}^2$$
 (13)

Riser flow from (8)

$$q_r = q_{dc} - \frac{d}{dt} \left(\rho_s a_m V_r \right) - \frac{d}{dt} \left(\rho_w (1 - a_m) V_r \right) \tag{14}$$

Summary

$$\frac{d}{dt} \left[\rho_s h_s V_{st} + \rho_w h_w V_{wt} + m c_p T \right]
= P + q_{fw} h_{fw} - q_s h_s$$
(1)

$$\frac{d}{dt}\left[\rho_s V_{st} + \rho_w V_{wt}\right] = q_{fw} - q_s \tag{4}$$

$$h_c(1 - x_r) \frac{d}{dt} (\rho_s a_m V_r) + \rho_w (1 - a_m) V_r \frac{dh_w}{dt}$$

$$- x h_c \frac{d}{dt} (\rho_w (1 - a_m) V_r) + \rho_s a_m V_r \frac{dh_s}{dt}$$

$$= P - x_r h_c q_{dc}$$

$$(10)$$

Choose p, V_w , and x_r as state variables.

Simulation Model

$$\begin{cases} e_{11} \frac{dp}{dt} + e_{12} \frac{dV_w}{dt} + e_{13} \frac{dx_r}{dt} = P + q_{fw} h_{fw} - q_s h_s \\ e_{21} \frac{dp}{dt} + e_{22} \frac{dV_w}{dt} + e_{23} \frac{dx_r}{dt} = q_{fw} - q_s \\ e_{31} \frac{dp}{dt} + e_{33} \frac{dx_r}{dt} = P - q_{dc} x_r h_c \end{cases}$$
(15)

$$e_{11} = \left(\frac{d\rho_s}{dp}h_s + \rho_s \frac{dh_s}{dp}\right) V_{st}$$

$$+ \left(\frac{d\rho_w}{dp}h_w + \rho_w \frac{dh_w}{dp}\right) V_{wt} + mc_p \frac{dT_s}{dp}$$

$$e_{12} = \rho_w h_w - \rho_s h_s$$

$$e_{13} = (\rho_s h_s - \rho_w h_w) V_r$$

$$e_{21} = \frac{d\rho_s}{dp} V_{st} + \frac{d\rho_w}{dp} V_{wt}$$

$$e_{22} = \rho_w - \rho_s$$

$$e_{23} = (\rho_s - \rho_w) V_r \frac{da_m}{dx_r}$$

$$e_{31} = \left[(1 - x_r) h_c \frac{h\rho_s}{dp} + \rho_s \frac{dh_s}{dp} \right] a_m V_r$$

$$+ \left[\rho_w \frac{dh_w}{dp} - x_r h_c \frac{d\rho_w}{dp} \right] (1 - a_m) V_r$$

 $e_{33} = [(1 - x_r)\rho_s + x_r\rho_w] h_c V_r \frac{da_m}{dr}$

Parameters

 $egin{array}{lll} V_{drum} & {
m drum\ volume} \ V_r & {
m riser\ volume} \ V_{dc} & {
m downcomer\ volume} \ m & {
m total\ metal\ mass} \ c_p & {
m specific\ heat\ of\ metal\ } \ k & {
m friction\ coefficient} \ \end{array}$

- 1. Introduction
- 2. First Order Model
 - 3. Shrink and Swell

4. Simulations

- 5. Experiments
- 6. Conclusions

Step in Fuel Flow




Figure 1. Responses to a step in fuel flow.

Step in Steam Flow




Figure 2. Response to a step

- 1. Introduction
- 2. First Order Model
 - 3. Shrink and Swell
 - 4. Simulations

5. Experiments

6. Conclusions

EXPERIMENTS


P16-G16 at Öresundsverket

Steinmuller boiler Stal-Laval turbine. Active power 160MW.

Controllers disconnected. PRBS like perturbations introduced in fuel flow, feedwater flow and steam valve at high and low load


Fuel Flow Changes at Low Load

88.02.05 - 17:15:22 nr: 1 hcopy meta




Turbine Valve Changes at Low Load

88.02.05 - 18:36:41 nr: 1 hcopy meta




Feedwater Flow Changes at Low Load

88.02.05 - 18:13:05 nr: 1 hcopy meta




Fuel Flow Changes at High Load

88.02.05 - 19:16:05 nr: 1 hcopy meta




Turbine Valve Changes at High Load

88.02.05 - 20:41:54 nr: 1 hcopy meta



Feedwater Flow Changes at High Load

88.02.05 - 19:45:37 nr: 1 hcopy meta



- 1. Introduction
- 2. First Order Model
- 3. Shrink and Swell
- 4. Simulations
- 5. Experiments
- 6. Conclusions

CONCLUSIONS

Promising results

Some details remain

Further experiments

Simplifications

Control design