



LUND UNIVERSITY

Flow-Rate Control of a Continuous Stirred Tank Reactor Start-Up and Large Disturbances

Axelsson, Jan Peter; Hagander, Per

1989

Document Version:

Publisher's PDF, also known as Version of record

[Link to publication](#)

Citation for published version (APA):

Axelsson, J. P., & Hagander, P. (1989). *Flow-Rate Control of a Continuous Stirred Tank Reactor: Start-Up and Large Disturbances*. (Technical Reports TFRT-7420). Department of Automatic Control, Lund Institute of Technology (LTH).

Total number of authors:

2

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

Flow-rate Control of a Continuous Stirred Tank Reactor - Start-up and Large Disturbances

Jan Peter Axelsson
Per Hagander

Department of Automatic Control
Lund Institute of Technology
May 1989

Department of Automatic Control Lund Institute of Technology P.O. Box 118 S-221 00 Lund Sweden		<i>Document name</i> INTERNAL REPORT	
		<i>Date of issue</i> May 1989	
		<i>Document Number</i> CODEN: LUTFD2/(TFRT-7420)/1-006/(1989)	
<i>Author(s)</i> Jan Peter Axelsson and Per Hagander		<i>Supervisor</i>	
		<i>Sponsoring organisation</i> STU	
<i>Title and subtitle</i> Flow-rate Control of a Continuous Stirred Tank Reactor. Start-up and Large Disturbances.			
<i>Abstract</i> <p>The non-linear character of the dynamics of a continuous stirred tank reactor is analysed in case of flow rate control. Analysis is made of a simple process model for continuous ethanol production using immobilized yeast, but the results carry over to most reactions with immobilized catalyst. An analytical solution of the bilinear state equations are given. The solution has a structure that makes it easy to calculate the evolution of reachable sets from different initial states. The insight obtained from analysis of reachability is used to derive a time-optimal control strategy. A bang-bang control law is obtained with a simple switch curve in the state space. It is found that start-up and large disturbances call for reversed control actions compared to control around the working point. The structure of the process model suggests application of exact linearization. However, analysis shows that such a transformation becomes singular in this case. Exact linearization is therefore of less value in this application.</p> <p>The paper is an extended abstract submitted to AIChE 89, San Fransisco, November 5-10, 1989.</p>			
<i>Key words</i>			
<i>Classification system and/or index terms (if any)</i>			
<i>Supplementary bibliographical information</i>			
<i>ISSN and key title</i>		<i>ISBN</i>	
<i>Language</i> English	<i>Number of pages</i> 6	<i>Recipient's notes</i>	
<i>Security classification</i>			

The report may be ordered from the Department of Automatic Control or borrowed through the University Library 2, Box 1010, S-221 03 Lund, Sweden, Telex: 33248 lubbis lund.

Flow-rate Control of a Continuous Stirred Tank Reactor Start-up and Large Disturbances

Jan Peter Axelsson and Per Hagander

Department of Automatic Control

Lund Institute of Technology

S-221 00 Lund, Sweden

Introduction

The continuous stirred tank reactor is a very general component that is used also in biotechnology applications. Enzymes in living cells act as catalysts, and they may be immobilized, recycled or continuously growing at the dilution rate. For biotechnology processes media concentrations and enzyme activity often vary considerably and feedback control is required for good economy. Continuous ethanol fermentation using alginate entrapped yeast was studied in the laboratory. The concentrations of the substrate sugar and the product ethanol were measured on-line and utilized for controlling the flow-rate through the fermentor, as described in a series of papers, (Axelsson *et al.*, 1982; Mattiasson *et al.*, 1983; Mandenius *et al.*, 1987). The linear controllers used were designed to compensate for the time-delays introduced in the sensors. Good control was shown for set point changes and in response to small disturbances, both with product and substrate concentration as controlled variable.

Models for the process are however nonlinear, actually bilinear, and for large disturbances nonlinear controllers are required. This paper shows that it is possible to use the structure of the solutions to describe the reachable sets of the system. Limited controllability is found on a line in the state space, actually related to reaction invariants. See eg. (Fjeld *et al.*, 1974; Waller and Mäkilä, 1981).

In the next section these reachable set expressions are then used to obtain a time optimal controller. The expressions are also compared with a lack of controllability obtained using the Lie brackets of differential geometry. The final section describes the transformations needed when applying exact linearization. The lack of controllability shows up as singularities in the transformations.

Process dynamics

Normalized mass balance equations for the continuous tank are

$$\begin{cases} \frac{dS}{dt} = -S + (1 - S)u \\ \frac{dE}{dt} = S - Eu \end{cases} \quad (1)$$

where S , E and u are sugar, ethanol and flow rate through the reactor, respectively. Note that these are non-negative quantities. Let

$$\begin{cases} z_1 = 1 - S \\ z_2 = 1 - S - E \end{cases} \quad (2)$$

which gives

$$\begin{cases} \frac{dz_1}{dt} = -(1+u)z_1 + 1 \\ \frac{dz_2}{dt} = -uz_2 \end{cases} \quad (3)$$

Integration of the equations gives

$$\begin{cases} z_1(t) = e^{-t}v(t)z_1(t_0) + w(t) \\ z_2(t) = v(t)z_2(t_0) \end{cases} \quad (4)$$

where

$$\begin{aligned} v(\tau) &= \phi(t, t - \tau) \\ w(t) &= \int_{t_0}^t e^{-\tau} v(\tau) d\tau \\ \phi(t, s) &= e^{-\int_s^t u(\tau) d\tau} \end{aligned} \quad (5)$$

Reachable Sets

The state-space is not completely reachable since $v(t) \in (0, \infty)$, and $z_2(t_0) = 0$ implies $z_2(t) = 0$ for any input signal. No trajectories pass the line $z_2 = 0$.

It is further interesting to regard the implication of the input u being limited to the interval $[0, d]$, as in the current real process. Denote by $\Omega(t, z(t_0))$ the subset of the state space that can be reached at time t from the point $z(t_0)$. In order to characterize Ω all possible $z_1(t)$ values are determined for a given $z_2(t)$ value, i.e. from (4) it follows that $v(t)$ is given by $z_2(t)$ and possible $w(t)$ values are obtained via $v_{[t_0, t]}$ from all possible input signals $u_{[t_0, t]}$.

Therefore introduce two extreme input signals

$$\begin{aligned} u^+(s) &= \begin{cases} d & s \in [0, \tau_1] \\ 0 & s \in (\tau_1, t] \end{cases} \\ u^-(s) &= \begin{cases} 0 & s \in [0, t - \tau_1] \\ d & s \in (t - \tau_1, t] \end{cases} \end{aligned} \quad (6)$$

satisfying the $v(t)$ constraint by

$$v(t) = e^{-\tau_1 d} \quad (7)$$

It is straight forward to calculate the corresponding functions v^+ , and v^- , and for any possible v function it actually holds that

$$v^-(\tau) \leq v(\tau) \leq v^+(\tau), \quad \tau \in [0, t] \quad (8)$$

and thus similarly for the corresponding w functions:

$$w^-(\tau) \leq w(\tau) \leq w^+(\tau), \quad \tau \in [0, t] \quad (9)$$

It can also be shown that for any w function fulfilling (9) there exists a corresponding input function u . Introduce by (4) the corresponding extremal z_1^+

and z_1^- functions. Now all possible $z_2(t)$ values together with their corresponding possible $z_1(t)$ values form the desired Ω set. All possible $z_2(t)$ values are obtained by letting τ_1 in (7) sweep the interval $\tau_1 \in [0, t]$. Since z_1^+ and z_1^- are the extreme values the boundary of Ω is generated by the (z_1^+, z_2) and (z_1^-, z_2) curves. Actually this requires $z_1 \geq 0$, i. e. $S \leq 1$. Back transformation gives the corresponding (S, E) -reachable sets shown in Figure 1. It should be noted that it also follows that the points on the boundary of the set are reached using control signals with only one switching point.




Figure 1. The reachable set as a function of time (left diagram: $t=0, 0.3, 1.5, 5$ and right diagram: $t=0, 0.3, 5$) for two different initial states.

Time Optimal Control

The reachable sets Ω can be used to develop optimal control strategies for different control objectives. In this section control to a set-point E_r in product concentration E is studied, and the criterion is chosen to be minimum time. As seen from the Figure 1. the sets increase their maximal E -value as time increases. For small t the maximum occurs at the lowest S -value, while the line $E = E_r$ is a tangent to the boundary curve, if a longer time is needed. The first case means that $u = 0$ is optimal, while the optimal control in the second case starts with a maximal u then switching to zero at time τ_1 . Those starting values that correspond to a tangent in the leftmost point, i.e. a switching at $\tau_1 = 0$ generate a switching curve in the state space. Simple calculations show that this curve is the line

$$E = E_r(1 - S) \quad (10)$$

The reachable sets have their minimal point for maximal S , at least above the maximal possible stationary $E = \frac{1}{1+d}$. This corresponds to maximal control signal during the whole time interval, which is thus the optimal strategy when starting from $E > E_r$. In summary it is thus proven that the following strategy is time-optimal:

$$u = \begin{cases} 0 & E_r(1 - S) < E < E_r \\ d & \text{otherwise} \end{cases} \quad (11)$$

In Figure 2. is shown the time-optimal elimination of a small and large disturbance. Both state space trajectories and resulting time functions are shown, and for comparison a simulation of a proportional controller is given in Figure 3. Notice for the large disturbance case that the time-optimal regulator starts off in the opposite direction as compared to the proportional regulator.




Figure 2. Time optimal elimination of a small and a large disturbance.




Figure 3. Elimination of a small and a large disturbance using limited proportional control.

Remark on exact linearization

The process model has a structure that at first sight suggests application of exact linearization, (Hunt, Su, and Meyer 1983). However, analysis shows that this methodology is of less value for design of the control law in this case.

The process model could be described as an interaction between a drift field f and a control field g

$$\dot{x} = f(x) + g(x)u(t) \quad (12)$$

where $x_1 = S$, $x_2 = E$ and

$$f(x) = \begin{pmatrix} -x_1 \\ x_1 \end{pmatrix} \quad g(x) = \begin{pmatrix} 1 - x_1 \\ -x_2 \end{pmatrix} \quad (13)$$

Controllability can be analysed with the aid of Lie brackets (Isidori, 1985). A necessary condition for controllability is that $g, f, [f, g], [f, [f, g]], \dots$, span the state space. Simple calculations give

$$\begin{aligned} [f, g] &= \frac{dg}{dx}f - \frac{df}{dx}g \\ &= \begin{pmatrix} -1 & 0 \\ 0 & -1 \end{pmatrix} \begin{pmatrix} -x_1 \\ x_1 \end{pmatrix} - \begin{pmatrix} -1 & 0 \\ 1 & 0 \end{pmatrix} \begin{pmatrix} 1 - x_1 \\ -x_2 \end{pmatrix} = \begin{pmatrix} 1 \\ -1 \end{pmatrix} \end{aligned} \quad (14)$$

and further bracketing $[f, [f, g]], [f, [f, [f, g]]], \dots [g, [f, g]] \dots$ etc., gives no new directions. Thus, the condition for controllability becomes

$$\det \begin{pmatrix} g(x), [f, g](x) \end{pmatrix} = \det \begin{pmatrix} 1 - x_1 & 1 \\ -x_2 & -1 \end{pmatrix} = -(1 - x_1 - x_2) \neq 0 \quad (15)$$

This shows that there is no higher order controllability on the line (15). Further, outside this line the system is controllable.

The fact that the dimension of the controllability space shrinks to one on the line (15) implies, of course, that no non-singular transformation can bring the system to a controllable form.

An example of such a transformation is

$$\begin{aligned} z_1 &= x_1 \cdot \frac{1 - x_1 - x_2}{(1 - x_1)^2} \\ z_2 &= x_2 \cdot \frac{1}{1 - x_1} \end{aligned} \quad (16)$$

and

$$u = \psi(x_1, x_2, v) = \frac{(1 - x_1)^2}{1 - x_1 - x_2} \cdot v + x_1 \cdot \frac{1 + x_1}{1 - x_1} \quad (17)$$

which brings the system to the Brunovsky form

$$\dot{z} = \begin{pmatrix} 0 & 0 \\ 1 & 0 \end{pmatrix} z + \begin{pmatrix} 1 \\ 0 \end{pmatrix} v(t) \quad (18)$$

Note, that the transformation is singular in two different ways. The stationary points (15) are mapped into a single point in the z -plane, $z = (0, 1)$. Further, the control law (17) will be singular if for instance linear state feedback from z is used.

The fact that the control variable is non-negative further complicates application of exact linearization. It is not clear how this limitation should be accounted for.

Concluding remarks

The results of this paper were obtained to describe the reversed control action required for large disturbances and startup of a continuous ethanol fermentation, but they carry over to most reactions with immobilized catalyst in a stirred tank reactor.

Acknowledgements

This work is based on experimental work done in collaboration with the Department of Biotechnology with partial support from the Swedish Board for Technical Development under contracts 82-3359 and 82-3494. We would also like to thank Bo Bernhardsson and Bengt Mårtensson for important suggestions on how to treat the problem.

References

- AXELSSON, J. P., P. HAGANDER, C. F. MANDENIUS and B. MATTIASSON (1982): "Computer control of sucrose concentration in a fermentor with continuous flow," in A. Halme (Ed.): *Modelling and Control of Biotechnical Processes - 1st IFAC workshop*, IFAC, Pergamon Press, Helsinki, Finland, pp. 273-280.

- FJELD, M., O. A. ASBJÖRNSSEN and K. J. ÅSTRÖM (1974): "Reaction invariants and their importance in the analysis of eigenvectors, state observability and controllability of the continuous stirred tank reactor," *Chemical Engineering Science*, **29**, 1917-1926.
- HUNT, L. R., R. SU and G. MEYER (1983): "Global transformation of nonlinear Systems," *IEEE Trans. Automatic Control*, **AC-28**, 24-31.
- ISIDORI, A. (1985): *Nonlinear Control Systems*, Springer Verlag.
- MANDENIUS, C. F., B. MATTIASSON, J. P. AXELSSON and P. HAGANDER (1987): "Control of ethanol fermentation carried out with alginate entrapped *Saccharomyces cerevisiae*," *Biotechnol. Bioeng.*, **29**, 941-949.
- MATTIASSON, B., C. F. MANDENIUS, J. P. AXELSSON, B. DANIELSSON and P. HAGANDER (1983): "Computer control of fermentations with biosensors," *Ann. NY Acad. Sci.*, pp. 193-196.
- WALLER, K and P. MÄKILÄ (1981): "Chemical reaction invariants and variants and their use in reactor modelling, simulation, and control," *Ind. Eng. Chem. Process Des. Dev.*, **20**, 1-11.