



LUND UNIVERSITY

Measurement of Fine Particle Emissions from Two Commercially Operated Medium Sized Biomass Fired Boilers

Pagels, Joakim; Gudmundsson, Anders; Bohgard, Mats; Strand, Michael; Lillieblad, Lena; Sanati, Mehri; Swietlicki, Erik

Published in:

[Publication information missing]

2000

[Link to publication](#)

Citation for published version (APA):

Pagels, J., Gudmundsson, A., Bohgard, M., Strand, M., Lillieblad, L., Sanati, M., & Swietlicki, E. (2000). Measurement of Fine Particle Emissions from Two Commercially Operated Medium Sized Biomass Fired Boilers. *[Publication information missing]*, 148-148.

Total number of authors:

7

General rights

Unless other specific re-use rights are stated the following general rights apply:

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117
221 00 Lund
+46 46-222 00 00

CHARACTERISATION OF FINE PARTICLE EMISSIONS FROM TWO
COMMERCIALY OPERATED MEDIUM SIZED BIOMASS FIRED BOILERS
J. Pagels*, A. Gudmundsson and M. Bohgard, Div. Aerosol Technology,
Lund University, PO Box 118, SE-221 00, Lund, Sweden. M. Strand, L.
Lillieblad and M. Sanati, Bioenergy Technology, Växjö University, 351 95
Växjö, Sweden. E. Swietlicki, Dept. Physics, PO Box 118, SE-221 00, Lund
University, Sweden.

There is a directive from the European Union limiting the particle concentration in air corresponding to PM10 and PM2.5 respectively to avoid negative effects on the human health and the environment. It is therefore of interest to minimize the particle emission also from biomass combustion in medium scale combustors. Ash-forming constituents have an effect on plant operation and emissions from the combustion process. The inorganic vapor present in the flue gas may also form and change the particle-phase via nucleation, chemical surface reaction and condensation. For instance, during grate combustion of straw (Christensen 1996) and fluidized-bed combustion of willow (Valmari 1998), submicrometer ash particles of KCl and K₂SO₄ were observed. Detailed information about fly ash particle characteristics and ash transformation mechanisms are desirable in order to develop methods to decrease both ash deposition problems and the fine particle emission.

Measurements on fine particle emissions were performed in two grate fired boilers of similar design. The boilers are designed for an effect of 1.0 and 1.5 MW respectively and were in commercial use during the measurements. Boiler no.1 was fueled with woodwaste (high humidity) and boiler no.2 was fueled with dry sawdust from furniture industry. A multicyclone after the burner removes coarse particles. All particle sampling were performed between the multicyclone and the stack. A dilution probe was used to sample the flue gases. A cyclone (calculated cut off point 4 micrometers) was used to remove coarse particles penetrating the multicyclone. Fine particle emissions were studied using an electrical mobility spectrometer (SMPS, TSI), a low pressure cascade impactor (Dekati) and a time of flight instrument (APS, TSI). The impactor substrates were analysed using PIXE in order to achieve size resolved elemental composition.

Preliminary results show a sub-micrometer mode between 100- 200 nm (number weighted size distribution) in both boilers. Particle concentrations (14 – 800 nm) in the flue gas range between 1 – 4*10⁷ particles per cm³.

K.A. Christensen, *Aerosol Sci. Technol.*, 1996, **25**, 185-199.
T. Valmari, E.I. Kauppinen, J. Kurkela, J.K. Jokiniemi, G. Sfiris, H. Revitzer,
J. Aerosol Sci. 1998, **29**, 445-459

We wish a poster presentation

Title of Paper: CHARACTERISATION OF FINE PARTICLE EMISSIONS FROM TWO COMMERCIALY OPERATED MEDIUM SIZED BIOMASS FIRED BOILERS

Name of Author submitting Paper: Joakim Pagels

Name of Author to whom all correspondence should be sent: Joakim Pagels

Name of Author presenting paper at conference: Joakim Pagels

Is the Presenting Author a graduate student within one year of graduation: no

| | | | |
|--------------|--|--|--|
| Author | Joakim Pagels | Anders Gudmundsson | Mats Bohgard |
| Title | | PhD | Professor |
| Organization | Div. Aerosol Technology, Lund University | Div. Aerosol Technology, Lund University | Div. Aerosol Technology, Lund University |
| Adress | PO Box 118 | PO Box 118 | PO Box 118 |
| City | Lund | Lund | Lund |
| Postal Code | SE- 221 00 | SE- 221 00 | SE- 221 00 |
| Country | Sweden | Sweden | Sweden |
| Phone | +46 46 222 40 14 | +46 46 222 40 75 | +46 46 222 80 16 |
| Fax | +46 46 222 46 19 | +46 46 222 46 19 | +46 46 222 46 19 |
| Email | Joakim.pagels@design.lth.se | Anders.Gudmundsson@design.lth.se | Mats.Bohgard@design.lth.se |

| | | | |
|--------------|--|--|--|
| Author | Erik Swietlicki | Mikael Strand | Lena Lilledahl |
| Title | PhD | | |
| Organization | Div. Nuclear Physics, Dept. Physics, Lund University | Bioenergy Technology, Växjö University | Bioenergy Technology, Växjö University |
| Adress | PO Box 118 | | |
| City | Lund | Växjö | Växjö |
| Postal Code | SE- 221 00 | 351 95 | 351 95 |
| Country | Sweden | Sweden | Sweden |
| Phone | +46 46 222 96 80 | 0470-70 80 00 | 0470-70 80 00 |
| Fax | +46 46 222 47 09 | 0470-832 17 | 0470-832 17 |
| Email | Erik.swietlicki@nuclear.lth.se | Michael.Strand@itn.vxu.se | Lena.Lillieblad@itn.vxu.se |

| | |
|--------------|--|
| Author | Mehri Sanati |
| Title | PhD |
| Organization | Bioenergy Technology, Växjö University |
| Adress | |
| City | Växjö |
| Postal Code | 351 95 |
| Country | Sweden |
| Phone | 0470-70 80 00 |
| Fax | 0470-832 17 |
| Email | Mehri.Sanati@ibp.vxu.se |

Authors 1,5 and 6 are students