



# LUND UNIVERSITY

## Papermaking

### Adaptive Control

Åström, Karl Johan

*Published in:*  
Systems and Control Encyclopedia

1987

*Document Version:*  
Publisher's PDF, also known as Version of record

[Link to publication](#)

*Citation for published version (APA):*  
Åström, K. J. (1987). Papermaking: Adaptive Control. In M. G. Singh (Ed.), *Systems and Control Encyclopedia: Theory, Technology, Applications* (pp. 3590-3591). Pergamon Press Ltd..

*Total number of authors:*  
1

#### General rights

Unless other specific re-use rights are stated the following general rights apply:  
Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal

Read more about Creative commons licenses: <https://creativecommons.org/licenses/>

#### Take down policy

If you believe that this document breaches copyright please contact us providing details, and we will remove access to the work immediately and investigate your claim.

LUND UNIVERSITY

PO Box 117  
221 00 Lund  
+46 46-222 00 00

the time of writing, however, international links operate either with LAPB or with a multiline procedure which also operates on several parallel lines, but which was developed before standardization of the multilink procedure.

X.95 specifies the call progress signals of public data networks—for the packet mode of operation, that is, the meaning of the cause field in clear, restart and reset packets.

X.121 specifies the international numbering plan for public data networks. In other words it describes the internal structure of the address fields used in call-establishment packets. Typically an address for a packet-mode DTE attached to a public packet-switched network is expressed as a one-digit prefix (e.g., 0, followed by a field of four digits to identify the network, and then followed by a few digits to identify the DTE in that network. Each network specifies the number of digits of its DTE address, with the possibility of giving short addresses to the same DTEs and longer ones to others.

9. Future Prospects

Although packet switching is now governed by a well-established set of international standards and has become a worldwide communication medium, some development is occurring, mainly in the direction of more interworking with other networks. With the progress made in modems which operate in synchronous mode over the public switched telephone network (PSTN), extensions of X.25 for operation via PSTN access ports are commercially planned. They are being studied by CCITT, in particular for teletex applications (direct communication between text-processing equipment).

Two directions of current research include interworking with local area networks and integration of packet-switching procedures into future integrated service digital networks (ISDNs). ISDNs should bring users an open choice between circuit switching and packet switching so that each is used where it best serves: circuit switching for long, continuous and fast transmission between two devices operating at the same speed; packet switching for slow or for spasmodic traffic, for communications between equipment with different characteristics and for multiplexing large numbers of diverse communications over individual network access ports.

See also: Distributed Computer Systems: An Introduction; Distributed Systems: Synchronization and Interprocess Communication; Switching Networks: General Structures

Bibliography

International Telegraph and Telephone Consultative Committee 1981 *Data Transmission over the Telephone Net-*

*work*, CCITT Yellow Book, Vol. VIII.1. International Telecommunication Union, Geneva  
International Telegraph and Telephone Consultative Committee 1981 *Public Data Networks*, CCITT Yellow Book, Vol. VIII.2. International Telecommunication Union, Geneva

R. Despres

Papermaking: Adaptive Control

The advanced control of important quality variables on a paper machine, such as basis weight and moisture content, are of major importance, since improvements of even fractions of a percent can represent substantial savings. The process dynamics include time delays. Operating conditions such as machine speed and the pressure distribution in the dryer sections may vary significantly. Large variations may also occur in the properties of pulp, and this can change drying conditions dramatically. All these variations result in changes in the process dynamics. A regulator which is well tuned at one operating condition and for one paper grade will not be optimal for other grades and other operating conditions. It is possible to compensate for variations in machine speed by gain scheduling, but this is not feasible for the paper grade, which is influenced by many different factors. This makes the paper machine an interesting candidate for adaptive control.

The steady-state control of the quality variables can conveniently be formulated as a minimum variance control problem. By reducing the variances of the quality variables, these may be brought closer to their optimum range, bringing savings in energy and raw materials and increases in production.

It was shown by Åström (1970) that the steady-state dynamics of the process and the disturbances could be described well by the model

$$A(q^{-1})y(t) = B(q^{-1})u(t-d) + C(q^{-1})e(t) \quad (1)$$

where  $y$  is a quality variable (basis weight or moisture content),  $u$  is a control variable (pulp flow or steam pressure) and  $\{e(t)\}$  is a sequence of independent random variables. Furthermore  $A$ ,  $B$  and  $C$  are polynomials of low degree in the backward shift operator  $q^{-1}$ . Good results with minimum variance controls based on identified model were also reported.

The model (1) is in a form which is well suited for the application of self-tuning regulators. Industrial feasibility studies of basis weight and moisture control using a simple self-tuner based on minimum variance control and least-squares estimation were carried out by Borisson and Wittenmark (1974) and Cegrell and Hedqvist (1975). There exist substantial disturbances which excite the process persistently, and thus good




Figure 1 Histogram for standard deviation in moisture for a self-tuner and a conventional fixed gain regulator (Fjeld and Wilhelm 1981)

parameter estimates can be obtained and simple exponential forgetting of past data works well. Commercial paper machine controls have also been equipped with self-tuning controllers (Fjeld and Wilhelm 1981). The performance improvements obtained in comparison with conventional control are illustrated in Fig. 1.

Bibliography

Åström K J 1970 *Introduction to Stochastic Control Theory*. Academic Press, New York  
Borisson U, Wittenmark B 1974 An industrial application of a self-tuning regulator. *Proc. IFAC Symp. Digital Computer Applications to Process Control*. Pergamon, Oxford  
Cegrell T, Hedqvist T 1975 Successful adaptive control of paper machines. *Automatica* 11, 53-59  
Fjeld M, Wilhelm R G 1981 Self-tuning regulators—The software way. *Control Eng.* 28, 99-102

K. J. Åström

Parabolic Systems

Any partial differential equation where the solution  $u$  is a function of a one-dimensional variable  $t$  (the time, generally) and of a second variable  $x$  (multidimensional, generally), and which may be written (explicitly or implicitly) in the form

$$\frac{du}{dt} + D(u(t, x), t, x) = g(t, x) \quad (1)$$

may be called a parabolic equation if  $u \rightarrow D(u, t, x)$  is an elliptic operator, where partial derivatives of second order with respect to  $x$  occur. We shall see that Eqn. (1) is "well posed" if the initial value is given, and if boundary conditions (at the boundary of the domain of  $x$ ) are given.

We present in this article only the linear case (where  $D(\cdot, t, x)$  is linear for any  $t$ ), after giving the best-known example of such equations, the heat equation. Finally we study variational inequalities, which are linear parabolic equations in a domain with a free boundary.

1. The Heat Equation

The heat equation is the "model" of linear parabolic equations. We present here this equation in a general case and we give explicit results in the simple case where the evolution domain is the whole space.

Let  $\Omega$  be an open set of  $\mathbb{R}^d$  modelling a heat conductor body. Assume that the initial temperature of the body is equal to  $f(x)$  for all  $x$  in  $\Omega$ ; that the boundary is maintained at the temperature  $\psi(t, x)$  at time  $t$  and position  $x$ ; and that there is a distributed heat source whose density with respect to time and space is a function  $g(t, x)$ . Then the evolution of the temperature  $u(t, x)$  of the body at time  $t$  and position  $x$  may be modelled by the following equation (where  $t > 0$ ):

$$\frac{\partial u}{\partial t} - m(x) \sum_{i=1}^d \frac{\partial}{\partial x_i} \left( M(x) \frac{\partial u}{\partial x_i} \right) = g(t, x), \quad x \in \Omega \quad (1a)$$

$$u(t, x) = \psi(t, x), \quad x \in \partial\Omega \quad (1b)$$

$$u(0, x) = f(x), \quad x \in \Omega \quad (1c)$$

where  $m$  and  $M$  are strictly positive functions describing the conductivity of the body. This kind of equation is studied in Sect. 2, (Eqn. (1) is a nonhomogeneous Dirichlet boundary condition).

Assume now that  $\Omega = \mathbb{R}^d$  (then (1b) has to be dropped) and  $m = M = 1$ . Then (1) may be written in the very simple form

$$\left. \begin{aligned} \frac{\partial u}{\partial t} - \sum_{i=1}^d \frac{\partial^2 u}{\partial x_i^2} &= g(t, x) \\ u(0, x) &= f(x) \end{aligned} \right\} \quad (2)$$

This is a Cauchy problem.

PROPOSITION 1. *If  $f$  and  $g$  are in  $L^\infty(\mathbb{R}^d)$  and  $L^\infty([0, +\infty) \times \mathbb{R}^d)$  respectively, there exists a unique bounded solution  $u$  of (2).*

Indeed, let

$$p = p(t, x, \xi) = (4\pi t)^{-d/2} \exp[-(x - \xi)^2/4t] \quad (3)$$

This function is called Green's function associated with the Laplacian in  $\mathbb{R}^d$ . It may be seen that  $p$  is a solution to

$$\left. \begin{aligned} \frac{\partial p}{\partial t} - \sum_{i=1}^d \frac{\partial^2 p}{\partial x_i^2} &= 0 \\ p(0, x) &= \delta(x - \xi) \end{aligned} \right\} \quad (4)$$

AN INVALUABLE SOURCE OF REFERENCE  
FOR RECOMMENDATION TO YOUR LIBRARY

# SYSTEMS & CONTROL ENCYCLOPEDIA

## Theory, Technology, Applications

The first comprehensive and up-to-date reference source on systems and control is now available from Pergamon Press with the regular publication of supplementary volumes scheduled to commence in early 1989.

Editor-in-Chief: MADAN G SINGH, *University of Manchester Institute of Science and Technology, UK*

The Encyclopedia is constructed around 25 subject areas and edited by a team of specialist subject editors - all of whom are regarded as pre-eminent in their respective fields. Articles are classified under three broad categories:

**THEORY** - modelling and simulation, control and systems theory, large-scale systems;

**TECHNOLOGY** - technology of measurement and control;

**APPLICATIONS** - technological, semi-technological and non-technological applications.

Particular emphasis has been given to industrial applications and this theme is continuous throughout. Modern industrial applications of control, such as automated production, air traffic control, computer-aided design etc., are extensively covered.

Extensive indexing and cross-referencing facilities ensure the precise location of topics of interest within the seven volumes of text, with the indexes supplied as an eighth volume. Full bibliographic referencing provides the reader with a substantial base from which to seek further information on specific topics of interest.

An essential primary source of reference for all departments and institutions, academic or industrial, that claim an interest in any aspect of the broad field of systems and control.

0 08 028709 3 Hardcover 8 volumes

This single offprint represents just one of over 1600 alphabetically arranged, authoritative articles and definitions, that together comprise the Systems & Control Encyclopedia.

FOR FURTHER DETAILS  
CONCERNING THE  
CONTENT,  
ORGANIZATION,  
STRUCTURE AND  
AUTHORSHIP OF THE  
SYSTEMS & CONTROL  
ENCYCLOPEDIA,  
PLEASE REQUEST OUR  
FREE COLOUR  
BROCHURE FROM  
YOUR NEAREST  
PERGAMON OFFICE.



**PERGAMON  
PRESS**

Headington Hill  
Hall, Oxford  
OX3 0BW, UK

Fairview Park,  
Elmsford, New York  
10523, USA

1987

Reprinted From

# SYSTEMS & CONTROL ENCYCLOPEDIA

Theory, Technology, Applications

Särtryck  
S-3590-  
Pergamon

Editor-in-Chief

**Madan G Singh**

*University of Manchester  
Institute of Science and Technology,  
Manchester, UK*

U-2 Action



**PERGAMON PRESS**

OXFORD · NEW YORK · BEIJING · FRANKFURT  
SÃO PAULO · SYDNEY · TOKYO · TORONTO